




6-33-53-12W5



Customer: PTRHTF20205	System Information	Sample Information
TERVITA BOX 38 NITON JUCTION, AB T0E 1S0 Canada Attn: John Kirsch Tel: (780)712-3382 E-Mail: jkirsch@tervita.com	System Volume: 4000 ltr Bulk Operating Temp: 320F / 160C Heating Source: Blanket: Fluid: PETRO CANADA PETRO-THERM Make: PARKER BOILER	Lab No: 02249080 Analyst: Peter Harteveld Sample Date: 10/30/18 Received Date: 11/02/18 Completed: 04/02/19

Recommendation: The condition of the fluid is poor. It is recommended to clean the system and replace the fluid. It looks like the fluid is degraded by oxidation. High viscosity, Acid Number and elevated 90% GCD temperature are indications of that. As a result of oxidation the fluid has become acidic which has resulted in corrosion (hence the high Fe content) and a high solids content (drop-out of carbonaceous material). Oxidation of the fluid can be the result of not having blanket gas on the expansion tank. Please verify proper operation of the blanket gas system.

Comments: Iron ppm levels are severe. PQ levels are severe. Pentane Insolubles levels are severely high. Acid Number (AN) is severely high. Visc @ 40°C is severely high. (GCD) 90% Distillation Point is marginally high.



Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
10/30/18	11/02/18	0y		419 / 215	306.4	330	1.47	2.93	695 / 368	806 / 430	925 / 496	3.21
Baseline Data				433 / 223		34.2	0.03		720 / 382	817 / 436	900 / 482	1.00





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
10/30/18	1189	0	0	0	0	0	0	0	0	0	4	5	0	0	0	0	12	0	1	0	3	0	1	0
Baseline Data			0	0						0			0	0					0				0	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.