



Customer: PTRHTF20187 Sample Information System Information **KEYERA ENERGY- SIMONETTE GAS** System Volume: 18000 ltr Lab No: 02254405 PLANT Bulk Operating Temp: 392F / 200C Analyst: Peter Harteveld PO BOX 58 Heating Source: Sample Date: 11/19/18 Received Date: 11/29/18 VALLEYVIEW, AB T0H 3N0 Canada Blanket: Fluid: PETRO CANADA PETRO-THERM Attn: Jason Wright Completed: 12/04/18 Make: PETROTECH Tel: (780)898-8643


E-Mail: jason wright@keyera.com

Recommendation: As a result of assumed mixing with a lighter fluid the following parameters are low and not representative for Petro-Therm: Viscosity, Flash Point and distillation curve. A Flash Point of 134 degrees is a safety concern in cases of an external leak. The low boiler vapor content is high (20.21%) and has to be lowered via venting. The fluid is suitable for further use but please start venting on a regular basis. Re-sample in 6 months.

Comments: (GCD) % < 335°C is severely high. (GCD) 10% Distillation Point is severely low. (GCD) 90% Distillation Point is severely low. COC Flash Point is severely low. Visc @ 40°C is severely low. (GCD) 50% Distillation Point is abnormally low.







Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.

Report ID: [02254405] (Generated: 12/07/2018 14:47:13) - Page 2 - Copyright 2018 Wearcheck Inc. All Rights Reserved.