


Customer: PTRHTF20207	System Information	Sample Information			
SEVEN GENERATIONS ENERGY LTD	System Volume: 8000 ltr	Lab No: 02255770			
7-11-064-03W6	Bulk Operating Temp: 302F / 150C	Analyst: Clinton Buhler			
GRANDE PRAIRIE, AB T8V 8H7	Heating Source:	Sample Date: 11/27/18			
Canada	Blanket:	Received Date: 12/07/18			
Attn: Justin Dery	Fluid: CHEVRON HEAT TRANSFER OIL 46	Completed: 12/19/18			
Tel: (587)435-4480	Make: PETRO TECH				
E-Mail: justin.dery@7genenergy.com					


Recommendation: it is understood that these results reflect the new fluid held in bulk storage on-site. Results indicate that the fluid is suitable for service, but care needs to be taken as there is nearly 2800 ppm water contamination. When placed into service, this fluid will need to vented to allow the steam to safely exit. If possible, drain any excess water from bottom of storage tank.

Comments: Water contamination levels are severely high.

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
11/27/18	12/07/18	0h		457 / 236	2799.8	37.8		0.140	735 / 390	831 / 444	918 / 492	1.29



Report ID: [02255770] (Generated: 12/19/2018 10:29:35) - Page 1 - Copyright 2018 Wearcheck Inc. All Rights Reserved.



Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.

Report ID: [02255770] (Generated: 12/19/2018 10:29:35) - Page 2 - Copyright 2018 Wearcheck Inc. All Rights Reserved.