

## H-1

## Customer: PTRHTF20208

Plains Midstream Canada PO Box 3210 Range Road 221

Fort Saskatchewan, AB T8L 2T2 Canada

Attn: Marlon Gonzalez Tel: (780)992-2724

E-Mail:

## **System Information**

System Volume: 1000 ml

Bulk Operating Temp: 500F / 260C

Heating Source:

Blanket:

Fluid: ESSO THERMOIL 32


Make:


## Sample Information

Lab No: 02258648 Analyst: Peter Harteveld Sample Date: 12/04/18 Received Date: 12/20/18 Completed: 12/24/18

Recommendation: This analysis report serves as the baseline reference for top-up with Petro-Therm. The fill of the system is a mix of Esso Oil 1156 and Thermoil 32. Interpretation of fluid condition is based on a generic ISO VG 5 fluid. Considering the main part of the fill is Esso Oil 1156, the condition reflected in this analysis report is normal. In this case the important parameters are Acid Number, water content, Fe (corrosion) and Pentane Insoluble (solids) content. The AN and water content are low. There is no Fe which means corrosion is not taking place. Solids content is moderately low. Please re-sample in 12 months. List oil service life, operating temperature, blanket gas info and system volume on the analysis request form when sending in the next sample.

Comments: (GCD) 10% Distillation Point is severely low. COC Flash Point is severely low. Visc @ 40°C is severely low. (GCD) 90% Distillation Point is abnormally low.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.