




## [JUPITER, KAKWA / 1-35-60-5-W6] H-751



| Customer: PTRHTF20175  | System Information  | Sample Information   |
|--|---|--|
| QUADRA CHEMICALS<br>7802 98 STREET<br>CLAIRMONT, AB T0H 0W0 Canada<br>Attn: Quadra Samples<br>Tel:<br>E-Mail: quadra_samples@quadra.ca | System Volume: 52000 gal<br>Bulk Operating Temp: 347F / 175C<br>Heating Source:<br>Blanket:<br>Fluid: PETRO CANADA PETRO-THERM<br>Make: | Lab No: 02263393<br>Analyst: Clinton Buhler<br>Sample Date: 12/20/18<br>Received Date: 01/21/19<br>Completed: 01/25/19 |

Recommendation: Sample results indicate that the fluid is suitable for continued service. % boil-off has increased since last sample which can indicate some thermal degradation. Regular venting of low boiling vapors from the expansion tank is recommended. Solids continues to be present. Please ensure blanket gas is operational. Please re-sample in 6 months

Comments:

| Sample Date   | Received Date | Fluid Age | Sample Location | Flash Point (COC) | Water (KF) | Viscosity (40°C) | Acid Number | Solids | GCD 10%   | GCD 50%   | GCD 90%    | GCD % < 335°C |
|---------------|---------------|-----------|-----------------|-------------------|------------|------------------|-------------|--------|-----------|-----------|------------|---------------|
|               | mm/dd/yy      |           |                 | °F/°C             | ppm        | cSt              | mg/KOH/g    | %wt    | °F/°C     | °F/°C     | °F/°C      | %             |
| 12/20/18      | 01/21/19      | 54m       | DISCHARGE       | 428 / 220         | 145.1      | 35.5             | 0.176       | 0.433  | 692 / 367 | 789 / 420 | 883 / 473  | 1.81          |
| 02/09/18      | 02/20/18      | 54m       |                 | 435 / 224         | 479.3      | 36.4             | 0.13        | 0.532  | 745 / 396 | 820 / 438 | 909 / 487  | 0.00          |
| 07/08/17      | 07/28/17      | 48m       |                 | 439 / 226         | 255.1      | 34.9             | 0.06        | 0.359  | 719 / 382 | 816 / 436 | 920 / 494  | 0.90          |
| 03/06/17      | 03/14/17      | 36m       |                 | 432 / 222         | 322.6      | 35.0             | 0.12        | 0.359  | 711 / 377 | 811 / 433 | 920 / 493  | 1.35          |
| 11/28/16      | 12/15/16      | 0m        | N2 LINE         |                   |            |                  |             |        | 476 / 246 | 780 / 416 | 971 / 522  | 20.79         |
| 11/27/16      | 12/15/16      | 0m        | N2 LINE         |                   |            |                  |             |        | 559 / 293 | 740 / 394 | 1004 / 540 | 22.49         |
| Baseline Data |               |           |                 | 433 / 223         |            | 34.2             | 0.03        |        | 720 / 382 | 817 / 436 | 900 / 482  | 1.00          |







| Sample Date   | Iron | Chromium | Nickel | Aluminum | Copper | Lead | Tin | Cadmium | Silver | Vanadium | Silicon | Sodium | Potassium | Titanium | Molybdenum | Antimony | Manganese | Lithium | Boron | Magnesium | Calcium | Barium | Phosphorus | Zinc |
|---------------|------|----------|--------|----------|--------|------|-----|---------|--------|----------|---------|--------|-----------|----------|------------|----------|-----------|---------|-------|-----------|---------|--------|------------|------|
| 12/20/18      | 73   | 0        | 0      | 0        | 0      | 0    | 0   | 0       | 0      | 0        | 2       | 0      | 0         | 0        | 0          | 0        | 2         | 0       | 0     | 0         | 1       | 0      | 0          | 0    |
| 02/09/18      | 186  | 0        | 0      | 0        | 0      | 0    | 0   | 0       | 0      | 0        | 3       | 4      | 0         | 0        | 0          | 0        | 4         | 0       | 0     | 0         | 6       | 0      | 1          | 0    |
| 07/08/17      | 75   | 0        | 0      | 0        | 0      | 0    | 0   | 0       | 0      | 0        | 2       | 2      | 0         | 0        | 0          | 0        | 2         | 0       | 0     | 0         | 0       | 0      | 0          | 0    |
| 03/06/17      | 96   | 0        | 0      | 0        | 0      | 0    | 0   | 0       | 0      | 0        | 2       | 2      | 0         | 0        | 0          | 0        | 2         | 0       | 0     | 0         | 2       | 0      | 0          | 0    |
| 11/28/16      |      |          |        |          |        |      |     |         |        |          |         |        |           |          |            |          |           |         |       |           |         |        |            |      |
| 11/27/16      |      |          |        |          |        |      |     |         |        |          |         |        |           |          |            |          |           |         |       |           |         |        |            |      |
| Baseline Data |      |          | 0      | 0        |        |      |     |         |        | 0        |         |        | 0         | 0        |            |          |           |         |       | 0         |         |        | 0          |      |

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]

### Gas Chromatography Distillation (GCD)



### % Boiling < 335°C



### Historical Comments

|          |  |
|----------|--|
| 02/09/18 | Sample results indicate that the fluid itself is suitable for continued service. However, Iron, pentane insolubles and water levels may indicate that there is corrosion ongoing or that possibly the sample was drawn from a dead leg that may not have been purged thoroughly. Consider investigating source of Iron and Water in system. Please ensure future samples are drawn from a hot, turbulent zone that is representative of system condition, and not from still, low lying zones with little fluid movement. Please ensure sample card is completely filled out with machine # and time on fluid. Re-sample in 6 months. Iron ppm levels are marginal. Pentane Insolubles levels are abnormally high. ppm Water contamination levels are marginally high. Water contamination levels are marginally high. |
| 07/08/17 | 90% GCD slightly elevated from new spec yet unchanged from previous sample. Elevated 90% GCD can indicate Oxidation of the fluid, however Acid Number is low which is ideal and Pentane Insolubles (solids) remains unchanged from last sample. Fluid is suitable for continued use. Please re-sample in 12 months.  |
| 03/06/17 | The 90% GCD temperature is slightly high. This is an indication of oxidation of the fluid. Please make sure the blanket gas system works properly. The fluid is in good condition and suitable for further use. Please re-sample in 12 months. (GCD) 90% Distillation Point is marginally high.  |
| 11/28/16 | This is a baseline read-out on the submitted sample. {not applicable} {not applicable} (GCD) % < 335°C is severely high. (GCD) 90% Distillation Point is severely high. (GCD) 10% Distillation Point is severely low. The sample contained >20% of a volatile hydrocarbon product (suspect pentane).   |
| 11/27/16 | This is a baseline read-out on the submitted sample. {not applicable} {not applicable} (GCD) % < 335°C is severely high. (GCD) 90% Distillation Point is severely high. (GCD) 10% Distillation Point is severely low. The sample contained >20% of a volatile hydrocarbon product (suspect pentane).   |