




## WANSON 600LNE



| Customer: PTRHTF40017  | System Information  | Sample Information   |
|--|---|--|
| INTERSNACK BV<br>HAVENSTRAAT 62<br>GELDERLAND<br>DOETINCHEM, GEL NETHERLANDS<br>Attn: Maintenance Manager<br>Tel:<br>E-Mail: | System Volume: 2600 ltr<br>Bulk Operating Temp: Not Specified<br>Heating Source:<br>Blanket:<br>Fluid: PETRO CANADA PURITY FG HEAT TRANSFER FLUID<br>Make: WANSON | Lab No: 02265954<br>Analyst: Philip Riley<br>Sample Date: 01/24/19<br>Received Date: 02/04/19<br>Completed: 02/19/19 |

Recommendation: COC low but improved from previous samples, was some form of venting done. 10% Dist point also marginally low. If can be done safely attempt to do further venting and raise both values. Viscosity trending downwards but within limits. Sample condition worsening showing signs of aging. Fit for further use and sample again at normal frequency

Comments: COC Flash Point is abnormally low. (GCD) 10% Distillation Point is abnormally low. (GCD) % < 335°C is marginally high.



| Sample Date   | Received Date | Fluid Age | Sample Location | Flash Point (COC) | Water (KF) | Viscosity (40°C) | Acid Number | Solids | GCD 10%   | GCD 50%   | GCD 90%   | GCD % < 335°C |
|---------------|---------------|-----------|-----------------|-------------------|------------|------------------|-------------|--------|-----------|-----------|-----------|---------------|
|               | mm/dd/yy      |           |                 | °F/°C             | ppm        | cSt              | mg/KOH/g    | %wt    | °F/°C     | °F/°C     | °F/°C     | %             |
| 01/24/19      | 02/04/19      | 5y        |                 | 370 / 188         | 35.1       | 28.3             | 0.400       | 0.050  | 644 / 340 | 776 / 414 | 885 / 474 | 8.61          |
| 11/21/17      | 11/27/17      | 4y        |                 | 356 / 180         | 12.3       | 29.0             | 0.38        | 0.075  | 669 / 354 | 776 / 413 | 865 / 463 | 5.86          |
| 11/15/16      | 11/24/16      | 3y        |                 | 345 / 174         | 34.9       | 30.2             | 0.676       | 0.061  | 692 / 367 | 806 / 430 | 908 / 487 | 4.38          |
| 06/30/15      | 07/03/15      | 2y        |                 | 374 / 190         | 23.3       | 33.0             | 0.61        | 0.048  | 716 / 380 | 820 / 438 | 927 / 497 | 2.00          |
| Baseline Data |               |           |                 | 459 / 237         |            | 37.12            | 0.90        |        | 721 / 383 | 807 / 431 | 892 / 478 | 1.5           |





| Sample Date   | Iron | Chromium | Nickel | Aluminum | Copper | Lead | Tin | Cadmium | Silver | Vanadium | Silicon | Sodium | Potassium | Titanium | Molybdenum | Antimony | Manganese | Lithium | Boron | Magnesium | Calcium | Barium | Phosphorus | Zinc |
|---------------|------|----------|--------|----------|--------|------|-----|---------|--------|----------|---------|--------|-----------|----------|------------|----------|-----------|---------|-------|-----------|---------|--------|------------|------|
| 01/24/19      | 17   | 0        | 0      | 0        | 2      | 0    | 1   | 0       | 0      | 0        | 0       | 0      | 0         | 0        | 0          | 0        | 0         | 0       | 0     | 0         | 0       | 0      | 13         | 1    |
| 11/21/17      | 12   | 0        | 0      | 0        | 0      | 0    | 3   | 0       | 0      | 0        | 0       | 0      | 0         | 0        | 0          | 0        | 0         | 0       | 0     | 0         | 0       | 0      | 8          | 0    |
| 11/15/16      | 15   | 0        | 0      | 0        | 0      | 0    | 5   | 0       | 0      | 0        | 0       | 0      | 0         | 0        | 0          | 0        | 0         | 0       | 0     | 0         | 0       | 0      | 14         | 0    |
| 06/30/15      | 50   | 0        | 0      | 0        | 0      | 0    | 4   | 0       | 0      | 0        | 0       | 0      | 0         | 0        | 0          | 0        | 0         | 0       | 0     | 0         | 0       | 0      | 12         | 1    |
| Baseline Data |      |          | 0      | 0        |        |      |     |         |        | 0        |         |        | 0         | 0        |            |          |           |         | 0     |           |         |        | 230        |      |

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



| Historical Comments |  |
|---------------------|--|
| 11/21/17            | Light molecules increased substantially over the 3 samples, may be worth de-gassing if possible to remove. Flash point consistently low but marginally improved on previous sample, but lower than expected. Suspect the fluid may have been partially changed (?) to increase the flash point. Suggest to monitor closely and if the flash point cannot be recovered look to change at next convenient point COC Flash Point is abnormally low. (GCD) 90% Distillation Point is abnormally low. |
| 11/15/16            | Oil is fit for service. Suggest sample at next scheduled maintenance interval. COC Flash Point is severely low.  |
| 06/30/15            | Oil appears for for further service, sample at next scheduled maintenance interval.  |

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.