




## DUPLEX FILTER


Customer: PTRHTF10028	System Information	Sample Information
PPG AEROSPACE 11601 UNITED ST MOJAVE, CA 93501 USA Attn: Phil Olson Tel: (661)232-6814 E-Mail: phil.olson@ppg.com	System Volume: 12 gal Bulk Operating Temp: 570F / 299C Heating Source: Blanket: Fluid: PETRO CANADA CALFLO AF Make:	Lab No: 02266546 Analyst: Ron LeBlanc Sample Date: 01/30/19 Received Date: 02/07/19 Completed: 02/11/19

Recommendation: Sample appears normal. Resample in 3 months.

Comments:



Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
01/30/19	02/07/19	0c		414 / 212	16.4	29.2	0.265	0.111	658 / 348	769 / 409	873 / 467	6.10
11/30/18	02/07/19	0c		410 / 210	81.8	29.5	0.457	0.152	656 / 347	770 / 410	873 / 467	6.44
02/19/18	03/02/18	0c		385 / 196	19.5	29.1	0.18	0.085	675 / 357	791 / 422	893 / 479	4.80
07/18/16	07/22/16	0c	BACK SIDE OF FILTER	370 / 188	8.2	30.1	0.296	0.077	678 / 359	785 / 419	896 / 480	3.48
Baseline Data				435 / 224		32.7	0.03		693 / 367	790 / 421	887 / 475	2.5





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc	
01/30/19	33	0	0	0	0	0	0	0	0	0	0	6	0	0	0	0	0	0	0	0	0	0	108	0	
11/30/18	13	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	85	0
02/19/18	29	0	0	0	0	0	0	0	0	0	0	3	0	0	0	0	0	0	0	0	0	0	106	1	
07/18/16	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	93	0	
<b>Baseline Data</b>			0	0						0			0	0					0					270	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



**Historical Comments**

11/30/18	
02/19/18	Slightly low Flash Point and initial boiling point but suitable for continued use.
07/18/16	The acid number is on the high side and the flash point is marginally low. It is expect that these numbers will continue to degrade over time. Recommend cleaning and changing out the system as previously discussed at the end of the year. Acid Number (AN) is abnormally high. COC Flash Point is marginally low.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.