



Recommendation: The fluid is in good condition and suitable for further use. Please re-sample in 12 months. When filling in the analysis request form please enter the service life of the fluid.


Comments:

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
02/10/19	02/19/19	0y	15-12-50-21WS	435 / 224	8.9	35.0	0.035	0.047	700 / 371	797 / 425	913 / 489	1.79
03/06/18	03/13/18	6у		432 / 222	5.8	34.9	0.05	0.140	729 / 387	823 / 440	923 / 495	0.28
02/23/17	03/03/17	Оy		432 / 222	9.9	35.2	0.157	0.155	719 / 381	810 / 432	910 / 488	1.23
07/17/16	07/18/16	0y	PUMP SUCTION	388 / 198	0.00	33.6	0.354	0.054	720 / 382	817 / 436	915 / 491	0.38
07/14/16	07/18/16	2у	EXPANSION TANK	374 / 190	48.1	32.0	0.488	0.057	711 / 377	795 / 424	888 / 475	0.29
12/09/15	12/14/15	2у		401 / 205	8.7	33.4	0.13	0.062	712 / 378	806 / 430	910 / 488	1.43
Baseline Data				433 / 223		34.2	0.03		720 / 382	817 / 436	900 / 482	1.00






Flash Point (°C)






Elemental anaysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



% Boiling < 335°C



## **Historical Comments**

03/06/18	The fluid is in good condition and suitable for further use. The 90% GCD temperature is elevated indicating fluid degradation by oxidation. Ensure blanket gas is in place. Please re-sample in 12 months. (GCD) 90% Distillation Point is marginally high.
02/23/17	The fluid is in good condition and suitable for further use. Please re-sample in 12 months.
07/17/16	TAN is elevated but other than that the fluid is in good condition and suitable for further use. Please re-sample in 6 months. Acid Number (AN) is abnormally high.
07/14/16	TAN is elevated but acceptable. The fluid is in good condition and suitable for further use. Please re-sample in 6 months. Acid Number (AN) is abnormally high. COC Flash Point is marginally low.
12/09/15	The fluid is in good condition and suitable for further use. A slight drop of Flash Point in combination with a marginal increase in GCD% <335C. indicates initial thermal degradation of the fluid. This is not a concern at this time. Please re-sample in 12 months.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.