


5 CALFLO TANK


Customer: PTRHTF20087	System Information	Sample Information				
Celanese Eva Performance Poly	System Volume: 0 ltr	Lab No: 02270300				
4405-101 AVE.	Bulk Operating Temp: Not Specified	Analyst: Gordon Susinski				
P.O. 428	Heating Source:	Sample Date: 02/20/19				
EDMONTON, AB T5J 2K1 Canada	Blanket:	Received Date: 02/27/19				
Attn: SYED TABREZ	Fluid: PETRO CANADA CALFLO AF	Completed: 03/04/19				
Tel: (780)468-8383	Make:					
E-Mail: syed.tabrez@celanese.com						

Recommendation: Depending on the actual oil service, the COC flash point may be below normal guidelines. The flash point is the lowest temperature at which the fluids vapor will momentarily ignite when contacted by an ignition source. Reduction is typically associated with thermal degradation of the heat transfer oil or possibly contamination. In this case we suspect contamination with a lighter hydrocarbon. This test result should not be the single determinant in the oils suitability for continued use, but should be interpreted using other results as well.

Comments: COC Flash Point is marginally low.

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
02/20/19	02/27/19	0h	OFFLINE SLIPSTREAM F	374 / 190	54.3	28.4	0.132	0.202	650 / 343	759 / 404	872 / 467	7.04





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.

Report ID: [02270300] (Generated: 03/04/2019 17:40:27) - Page 2 - Copyright 2019 Wearcheck Inc. All Rights Reserved.