



ROSKILDEVEJ 16

Customer: PTRHTF40094	System Information	Sample Information
PETROCHEM A/S SMEDELAND 22 GLOSTRUP, DENMARK Attn: MOGENS HNASEN/JOHN CLIFF Tel: 170707881 E-Mail: mh@petrochem.dk	System Volume: 8000 gal Bulk Operating Temp: Not Specified Heating Source: Blanket: Fluid: HEAT TRANSFER FLUID ISO 32 Make: SCHILLER ENERGI	Lab No: 02270620 Analyst: Philip Riley Sample Date: 02/05/19 Received Date: 02/28/19 Completed: 03/04/19

Recommendation: Not a Petro-Canada fluid so no data to compare against, cannot give full and informed diagnosis.

Comments:

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
02/05/19	02/28/19	8y		414 / 212	0.7	30.2	0.617	0.039	705 / 374	807 / 431	912 / 489	2.52
Baseline Data				410 / 210		32	0.41		707 / 375	802 / 428	910 / 488	1.5



