




# LINE 1



Customer: PTRHTF20031	System Information	Sample Information
MCCAIN FOODS PORTAGE PO BOX 220 1 McCain Avenue PORTAGE LA PRARIE, MB R1N 3B5 Canada Attn: Mark Nelissen Tel: x:	System Volume: 19000 ltr Bulk Operating Temp: 540F / 282C Heating Source: Blanket: Fluid: PETRO CANADA CALFLO HTF Make: KONUS-KESSEL	Lab No: 02271872 Analyst: Yutong Gao Sample Date: 03/04/19 Received Date: 03/07/19 Completed: 03/08/19

Recommendation: The current fluid condition have been improved after the system venting in the last week of Feb. The viscosity is normal, the contaminants such as water, dirt are minimum. The acid number is extremely low indicating minimum oil oxidation. The flash point is still lower than the fresh fluid due to the thermal cracking at high bulk fluid temperature. Please continue to run the fluid and conduct the system venting as a routine maintenance activity, take one sample in 6 months to monitor the conditions.

Comments: COC Flash Point is abnormally low. (GCD) % < 335°C is marginally high. (GCD) 10% Distillation Point is marginally low.

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
03/04/19	03/07/19	3y	2 PRIMARY PUMP DISCH	345 / 174	10.0	28.8	0.009	0.109	650 / 343	790 / 421	900 / 482	8.33
08/09/18	08/15/18	3y	#2 THERMAL OIL PUMP	316 / 158	17.1	28.4	0.021	0.021	679 / 360	800 / 427	909 / 487	5.52
12/29/16	01/06/17	1y	#2 PRIMARY PMP DISCH	356 / 180	28.9	31.2	0.036	0.039	699 / 371	817 / 436	931 / 499	3.65
08/21/16	08/31/16	1y	#2 PUMP DISCHARGE	403 / 206	19.2	31.6	0.040	0.077	703 / 373	807 / 431	916 / 491	3.06
12/28/15	01/06/16	4y	#2 PRIMARY PUMP DIS	374 / 190	7.0	35.9	0.04	0.071	693 / 367	803 / 428	897 / 481	4.07
04/09/15	04/13/15	0y		228 / 109	18.8	27.9	0.038	0.039	622 / 328	763 / 406	877 / 470	10.93
Baseline Data				448 / 231		35.20	.1		712 / 378	810 / 432	910 / 488	1.75







Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc	
03/04/19	9	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	29	0	
08/09/18	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	27	0
12/29/16	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	38	0
08/21/16	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	49	0
12/28/15	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	46	0
04/09/15	7	0	0	0	0	0	0	0	0	0	0	2	0	0	0	0	0	0	0	0	0	0	0	0	0
Baseline Data			0	0						0			0	0					0					280	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]

### Gas Chromatography Distillation (GCD)



### % Boiling < 335°C



### Historical Comments

08/09/18	The current fluid has normal viscosity, acid number and the distillation points. However, the fluid has high content of the low boiler due to the thermal cracking at the 285 C bulk working temperature. Please conduct a longer and more efficient system venting and take one sample in 6 months to monitor the conditions. It is also better to get the AIT test done to verify the property. COC Flash Point is severely low.
12/29/16	The fluid has adequate viscosity, TAN, solid content and the GCD distillation point. The flash point is reduced a little bit from the result in Summer 2016, but the oil is suitable for the further run. Please continue to do the effective system venting to release the low boilers.
08/21/16	The current fluid have adequate viscosity, flash point, distillation points. The water and solid contents are very low. Please keep conducting the current maintenance and venting process. Take one sample in 9~12 months to monitor the conditions.
12/28/15	The current fluid is good for future use. The viscosity, TAN, water level, solid level and distillation points are all normal. The reduced flash point indicates the slightly fluid thermal cracking from the constant ~285C high operation temperature. Like what has discussed in the past, please find an effective way to vent the low boiler (light end fluid) out of the system as a routine maintenance practice.
04/09/15	The flash point is further reduced, but the other parameters are very similar to the last samples. Not sure how many venting process has been done between Jan and April. The effective vening needs to be conducted as soon as possible. As per discussed, please send one sample for the AIT test to confirm the current fluid conditions. (GCD) 10% Distillation Point is severely low. COC Flash Point is severely low. (GCD) % < 335°C is marginally high. (GCD) 90% Distillation Point is marginally low.