

Tidewater	System Vo
21 Oxford PI.	Bulk Opera
Alder Flats, AB T0C 0A0 Canada	Heating So
Attn: Travis Smith	Blanket:
Tel: (780)679-2498	Fluid: CHE
E-Mail: tsmith@tidewatermidstream.com	Make: PRO


ulk Operating Temp: 345F / 174C eating Source: lanket: luid: CHEVRON HEAT TRANSFER OIL 22 lake: PROPAEK


Sample Informa Lab No: 02286540 Analyst: Terry Veenstra Sample Date: 04/25/19 Received Date: 05/22/19 Completed: 05/27/19

Recommendation: Acid Number is severely high, GCD Distillation number is severely high for 10% and 50%, Viscosity is high. Oxidation has resulted in increased viscosity, increased TAN and elevated GCD tests. Ensure gas blanket is in place to prevent oxidation of fluid from occurring. Consider sweetening oil in system with new oil.

Comments: Acid Number (AN) is severely high. (GCD) 10% Distillation Point is severely high. (GCD) 50% Distillation Point is severely high. Visc @ 40°C is severely high. (GCD) 90% Distillation Point is abnormally high.







Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.