



## [NORBORD GP / LSD2-6-70-SW6] GTS FURNACES

Customer: PTRHTF20184	System Information	Sample Information
NORBORD BAG 6700 HIGHWAY 40 S GRAND PRAIRIE, AB T8V 6Y9 Canada Attn: Doug McDonald Tel: (780)831-2573 E-Mail: doug.mcdonald@norbord.com	System Volume: 0 gal Bulk Operating Temp: 518F / 270C Heating Source: Blanket: Fluid: PETRO CANADA PETRO-THERM Make: GTS	Lab No: 02290661 Analyst: Gordon Susinski Sample Date: 06/06/19 Received Date: 06/12/19 Completed: 06/17/19

Recommendation: (GCD) 90% Distillation Point is marginally high. Otherwise results are normal. Re sample at the next interval and continue to monitor.

Comments: (GCD) 90% Distillation Point is marginally high.

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
06/06/19	06/12/19	1y		406 / 208	27.5	35.6	0.042	0.059	717 / 381	815 / 435	927 / 497	0.68
Baseline Data				433 / 223		34.2	0.03		720 / 382	817 / 436	900 / 482	1.00



