




API BOILER



Customer: PTRHTF30020	System Information	Sample Information
IKO INDUSTRIES HAWKESBURY 1451 SPENCE ROAD HI-PARTS-HAWK YARD HAWKESBURY, ON K6A 3T4 Canada Attn: Roy Paquette Tel: (613)632-8581 E-Mail: roy.paquette@iko.com	System Volume: 25000 ltr Bulk Operating Temp: 518F / 270C Heating Source: Blanket: Fluid: PETRO CANADA PETRO-THERM Make: INDUSTRIAL	Lab No: 02297698 Analyst: Pierre Castagne Sample Date: 07/12/19 Received Date: 07/18/19 Completed: 07/22/19 Pierre Castagne pierre.castagne@petrocanadalsp.com

Recommendation: You have trace of asphalt in the sample, carbon buildup (GCD @90%) are high, the oil is oxidising, viscosity is closer to ISO 46, Pentane Insolubles are high. Recommendation: The oil as reach t's usefull life, recommend draining the system, cleaning and flushing the system and refill with PetroTherm.

Comments: Pentane Insolubles levels are severely high. Acid Number (AN) is abnormally high. (GCD) 90% Distillation Point is abnormally high.




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
07/12/19	07/18/19	10y		414 / 212	41.0	40.4	0.616	0.600	711 / 377	812 / 433	929 / 498	0.93
10/15/18	10/18/18	10y		403 / 206	16.7	35.7	0.02	0.035	725 / 385	820 / 438	932 / 500	0.00
02/15/18	02/22/18	10y		410 / 210	6.8	37.6	0.03	0.075	693 / 367	809 / 432	931 / 500	4.24
05/03/17	05/11/17	10y	HOT OIL BOILER	410 / 210	8.8	37.3	0.191	0.064	714 / 379	820 / 438	976 / 525	1.23
07/13/16	07/18/16	10y	API HOT OIL HEATER	363 / 184	0.00	37.5	0.110	0.065	712 / 378	800 / 427	925 / 496	0.00
Baseline Data				433 / 223		34.2	0.03		720 / 382	817 / 436	900 / 482	1.00





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
07/12/19	6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1
10/15/18	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
02/15/18	18	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	3
05/03/17	13	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2
07/13/16	16	0	0	0	1	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	2
Baseline Data			0	0						0			0	0					0				0	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments	
10/15/18	Les fractions Lourdes (GCD @90%) sont élevées, les fractions lourdes augmentent la viscosité, favorise les dépôts de carbone. (GCD) 90% Distillation Point is abnormally high.
02/15/18	High boilers (GCD @90%), increase oil viscosity, and carbon deposit. Deposit, settle in low flow/disturbance areas and foul heat exchange surfaces. Looking at the curves, it appears that a mixture of another oil with lower viscosity could have been introduced in the system. (GCD) 90% Distillation Point is abnormally high.
05/03/17	The sample has trace of Vanadium, the Low boilers GCD @10% are within specification (this could be the result of topping-up the oil) although the flash point is lower than the Petro-Therm oil specification (210°C versus 225°C specification), this suggests some oil cracking is taking place. The High boilers GCD @ 90% are higher than the specification (524.6 versus 482 specifications); this normally causes the viscosity of the oil to increase and carbon deposits. (GCD) 90% Distillation Point is severely high.
07/13/16	(GCD) 90% Distillation Point is marginally high. COC Flash Point is significantly low. (GCD) 90% Distillation Point is marginally high. COC Flash Point is marginally low.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.