

## [#1 INLET TO TANK 104] HEAT TRANSFER

## Customer: PTRHTF10217

HOLLY FRONTIER ASPHALT 2411 N FREEMAN ARTESIA, NM 88210 USA

Attn: Roger Kilpatrick Tel: (575)748-1368

E-Mail: roger.kilpatrick@hollyfrontier.com

## **System Information**

System Volume: 0 gal

Bulk Operating Temp: 380F / 193C

Heating Source:

Blanket:

Fluid: HEAT TRANSFER FLUID ISO 46

Make: AMERICAN HEAT


## Sample Information


Lab No: 02298211

Analyst: Gaston Arseneault Sample Date: 07/11/19 Received Date: 07/19/19 Completed: 07/20/19

Recommendation: The fluid was described as a mixture of various products over the last 10 years. It does not appear to have been contaminated with asphalt since the viscosity is somewhat within an acceptable range and Vanadium is not present. The oil is heavily oxidized (degraded) however as the Acid Number is very high and the amount of solids (insoluble) is high. We don't think the system will need a full cleaning unless you see signs of obstructed jackets or pipes or reduced furnace efficiency. If no actions are to be taken before the 2020 shut down, we suggest to plan for a drain, flush and refill in 2020. If there is money in the budget for a partial fluid replacement in 2019 this would help reduce the need for a flush in 2020. In this case we recommend to replace 30% of the oil with fresh Petro-Therm in order to reduce the acidity level and concentration of debris in the oil.

Comments: Pentane Insolubles levels are severely high. COC Flash Point is severely high. Acid Number (AN) is severely high.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.