


## **NEW HEATER**

Customer: PTRHTF30137	System Information	Sample Information
McAsphalt Industries LTD 950 Boulevard Gérard-Cadieux Salaberry-de-Valleyfield, QC J6T 6L4 Canada Attn: Service Manager Tel: E-Mail:	System Volume: 0 ltr Bulk Operating Temp: Not Specified Heating Source: Blanket: Fluid: NOT GIVEN Make:	Lab No: 02300940 Analyst: Behshad Sabah Sample Date: 08/05/19 Received Date: 08/06/19 Completed: 08/09/19

Recommendation: High TAN, High Pantene Insoluble, and high viscosity all indications of oil oxidation. the Esso Teresstic which is in the system is not a heat transfer oil. the oil acidity will corrode the piping and fittings with the risk of pinholes and leaks. should monitor the system and be ready to changeout to a HTF fluid.

Comments: Pentane Insolubles levels are severely high. Acid Number (AN) is abnormally high.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.

Report ID: [02300940] (Generated: 08/09/2019 10:04:20) - Page 2 - Copyright 2019 Wearcheck Inc. All Rights Reserved.