



HOT OIL SYSTEM

Customer: PTRHTF10140

PABCO ROOFING PRODUCTS 1718 THORNE RD

TACOMA, WA 98421-3207 USA

Attn: Aziza Radwan Tel: (253)284-1205

E-Mail: aziza.radwan@pabcoroofing.com

System Information

System Volume: 300 gal

Bulk Operating Temp: 400F / 204C

Heating Source:

Blanket:

Fluid: HEAT TRANSFER FLUID ISO 46

Make: CEI


Sample Information

Lab No: 02303259 Analyst: Ron LeBlanc Sample Date: 05/22/19 Received Date: 08/19/19 Completed: 08/28/19

Recommendation: It appears the oil has been over heated. Lighter fractions are present as the GCD 90% distillation point is low. Pentane insolubles could be present due to a sample taken without purging oil before sample drawn. Take another sample in 1 month to review.

Comments: Pentane Insolubles levels are severely high. Acid Number (AN) is abnormally high. (GCD) 90% Distillation Point is abnormally low.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.