

[INDOOR] 433-0010

Customer: PTRHTF20221

McAsphalt Industries Ltd.

385 Softley Rd

Winnipeg, MB R2J 0R7 Canada

Attn: Eugene Langdon Tel: (204)233-1424

E-Mail: elangdon@mcasphalt.com

System Information

System Volume: 12000 ltr

Bulk Operating Temp: 392F / 200C

Heating Source:

Blanket:

Fluid: PETRO CANADA PETRO-THERM


Make: HEATEC


Sample Information

Lab No: 02305733 Analyst: Behshad Sabah Sample Date: 08/26/19 Received Date: 08/29/19 Completed: 09/04/19

Recommendation: High TAN, Pentane Insoluble, , and oil viscosity are the indication of high oxidation. High Iron is the indication of the corrosion. there is a chance of pinholes and product leak. please change the oil

Comments: Iron ppm levels are severe. PQ levels are abnormal. Pentane Insolubles levels are severely high. Acid Number (AN) is severely high. Visc @ 40°C is severely high.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.