




## B150 GROEN



Customer: PTRHTF10078	System Information	Sample Information
WEST FORK CREATIONS 15 PEPSI DRIVE RED LODGE, MT 59068 USA Attn: Sean Keeney Tel: (406)426-3060 E-Mail: foodsafety@kingscupboard.com	System Volume: 55 gal Bulk Operating Temp: 475F / 246C Heating Source: Blanket: Fluid: PETRO CANADA PURITY FG HEAT TRANSFER FLUID Make: STERLCO	Lab No: 02306725 Analyst: Ron LeBlanc Sample Date: 08/22/19 Received Date: 09/06/19 Completed: 09/10/19

Recommendation: Sample is improved from previous sample. Sample looks normal. Re-sample in 3 months.

Comments:




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
08/22/19	09/06/19	6m	DRAIN	410 / 210	0.00	29.0	0.557	0.223	690 / 366	803 / 429	888 / 476	4.50
07/22/19	08/01/19	1m	DRAIN VALVE	313 / 156	20.9	28.7	0.521	0.185	690 / 366	801 / 427	885 / 474	4.31
06/28/18	07/23/18	5m	OIL DRAIN	349 / 176	78.3	30.8	0.905	1.24	685 / 363	803 / 428	897 / 481	5.51
08/15/17	08/25/17	12m		381 / 194	137.7	36.1	0.858	2.70	701 / 372	808 / 431	901 / 483	3.70
05/31/16	06/09/16	10m	DRAIN PLUG	419 / 215	83.6	37.4	0.66	0.707	709 / 376	805 / 429	895 / 480	2.10
12/01/14	12/12/14	8m	DRAIN	412 / 211	18.6	37.1	0.26	0.102	724 / 384	817 / 436	911 / 488	0.65
Baseline Data				459 / 237		37.12	0.90		721 / 383	807 / 431	892 / 478	1.5





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
08/22/19	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	95	0
07/22/19	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	94	1
06/28/18	6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	84	6
08/15/17	17	0	0	0	1	1	0	0	0	0	0	2	0	0	0	0	0	0	0	0	0	0	92	18
05/31/16	12	0	0	0	1	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	93	17
12/01/14	11	0	0	0	0	2	0	0	0	0	3	0	0	0	0	0	0	0	0	4	1	0	109	52
Baseline Data			0	0						0			0	0					0				230	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



### Historical Comments

07/22/19	The COC Flash Point has dropped over the last 2 samples. It might be due to where the sample is being taken or not purging enough oil before sample is drawn. The oil could have been overheated or severely taken up to operating temperature rapidly. Viscosity has dropped significantly in the last 2 samples. If possible add fresh oil to bring viscosity and COC Flash Point up. Take another sample and send in to verify results. COC Flash Point is severely low.
06/28/18	Pentane Insolubles levels are severely high. COC Flash Point is severely low. A small charge of new oil can bring the COC flash point up. Resample and purge extra oil out of sample port to get a good sample to confirm numbers. Pentane Insolubles levels are severely high. COC Flash Point is severely low.
08/15/17	Pentane insoluble have increased significantly. Determine entry point. Check filtration if equipped. Make sure sample was taken properly. Let the oil run freely for a short amount of time before capturing in container. Pentane Insolubles levels are severely high. COC Flash Point is marginally low.
05/31/16	Sample is in good condition but the pentane insolubles are high which is an indication of oxidation and sludging may be occurring. Re-sample at the next maintenance interval. Pentane Insolubles levels are severely high.
12/01/14	Zinc is fluctuating between samples. Determine the origin of Zn. . H2O is lower on this sample. TAN has stayed stable in the last 2 samples. Continue to sample oil at normal interval. Zinc ppm levels are severely high.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.