

WANSON TPL800LNE

Customer: PTRHTF40114

DIFFUTHERM B.V. SMARAGDWEG 50

HAPERT, 5527 LB Netherlands

Attn: Wilbert Snijers

Tel:

E-Mail: w.snijers@klt.nl

System Information

System Volume: 6000 ltr

Bulk Operating Temp: 455F / 235C

Heating Source:

Blanket:

Fluid: PETRO CANADA PETRO-THERM

Make: WANSON


Sample Information

Lab No: 02307724 Analyst: Philip Riley Sample Date: 09/05/19 Received Date: 09/11/19 Completed: 09/15/19

Recommendation: Product in good condition within all fluid parameters. Re-sample at normal frequency, no action needed based on sample


Comments:

| Sample Date | Received Date | Fluid Age | Sample Location | Flash Point (COC) | Water (KF) | Viscosity (40°C) | Acid Number | Solids | GCD 10% | GCD 50% | GCD 90% | GCD % < 335°C |
|-------------|---------------|-----------|-----------------|-------------------|------------|------------------|--------------|--------|-----------|-----------|-----------|---------------|
| | mm/dd/yy | | | °F/°C | ppm | cSt | mg/KOH/ g | %wt | °F/°C | °F/°C | °F/°C | % |
| 09/05/19 | 09/11/19 | 6y | | 432 / 222 | 33.7 | 34.6 | 0.046 | 0.075 | 722 / 383 | 803 / 428 | 892 / 478 | 0.00 |
| 10/02/18 | 10/10/18 | 0y | | 442 / 228 | 23.4 | 34.7 | 0.02 | 0.313 | 727 / 386 | 805 / 429 | 887 / 475 | 0.00 |
| 10/05/17 | 10/12/17 | 4y | | 424 / 218 | 28.6 | 34.8 | 0.010 | 0.067 | 721 / 383 | 812 / 433 | 912 / 489 | 0.91 |
| 10/11/16 | 10/24/16 | Зу | PTRHTF40114 | 432 / 222 | 29.1 | 35.1 | 0.056 | 0.089 | 723 / 384 | 814 / 435 | 917 / 491 | 0.39 |
| 11/10/15 | 11/23/15 | 2y | PTRHTF40114 | 446 / 230 | 46.2 | 35.0 | 0.05 | 0.368 | 721 / 383 | 809 / 432 | 908 / 487 | 0.46 |
| 10/24/14 | 10/30/14 | 0y | | 439 / 226 | 97.6 | 34.9 | 0.072 | 0.013 | 720 / 382 | 816 / 436 | 922 / 495 | 0.41 |
| | | Baseline | Data | 433 / 223 | | 34.2 | 0.03 | | 720 / 382 | 817 / 436 | 900 / 482 | 1.00 |





Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



| Historical Comments | | | | | | | | | |
|---------------------|---|--|--|--|--|--|--|--|--|
| 10/02/18 | All parameters within acceptable limits. Fluid fit for further use | | | | | | | | |
| 10/05/17 | All parameters tested in line with expectations. Continued use based on oil analysis reviewed | | | | | | | | |
| 10/11/16 | Oil appears in good condition and fit for further service. Identify where levels of copper are originating from.Copper ppm levels are noted. | | | | | | | | |
| 11/10/15 | Oil appears to be in good condition and fit for further service. Suggest sample at next scheduled maintenance interval. | | | | | | | | |
| 10/24/14 | Oil appears to be in very good condition and fit for further service. Sample at next scheduled maintenance interval. (GCD) 90% Distillation Point is marginally high. | | | | | | | | |

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.