

[LSD / 09-15-084-14W5] TIDEWATER SEAL LAKE

Customer: PTRHTF20224

Tidewater Midstream 09-15-084-14W5

Slave Lake, AB T0G 2A4 Canada

Attn: Barry Anderson Tel: (780)514-8404

E-Mail:

banderson@tidewatermidstream.com

System Information

System Volume: 0 gal

Bulk Operating Temp: Not Specified

Heating Source:

Blanket:

Fluid: PETRO CANADA PETRO-THERM

Make: PROPAK


Sample Information


Lab No: 02308321 Analyst: Peter Harteveld Sample Date: 09/05/19 Received Date: 09/13/19

Completed: 09/17/19

Recommendation: The fluid is in good condition and suitable for further use. Acid Number is elevated but since the AN test is not the most accurate, the condition of a fluid can't be judged on AN alone. The Fe content is low which means there is no corrosive wear ongoing. Please re-sample in 6 months. When sending in the next sample please list system volume and operating temperature of the fluid on the analysis request form.

Comments: Acid Number (AN) is abnormally high.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.