

P1207

Customer: PTRHTF30142

McAsphalt Industries Ltd. 15 McCurdy Avenue

Dartmouth, NS B3B 1C4 Canada

Attn: Tim Bona Tel: (902)210-0070

E-Mail: tbona@mcasphalt.com

System Information

System Volume: 500 gal

Bulk Operating Temp: 360F / 182C

Heating Source:

Blanket:

Fluid: ESSO TERESSTIC ISO 100


Make: HEATEC


Sample Information

Lab No: 02308714 Analyst: Behshad Sabah Sample Date: 09/11/19 Received Date: 09/16/19 Completed: 10/28/19

Recommendation: High TAN, Acid number and Pentane Insoluble ,and high viscosity indicate highly oxidized oil. the high iron PPM shows the piping corrosion. recommend to change the oil as there is a chance of pinhole and oil leak.

Comments: PQ levels are abnormal. Iron ppm levels are abnormal. Pentane Insolubles levels are severely high. Sodium ppm levels are severely high. Acid Number (AN) is severely high. (GCD) 10% Distillation Point is severely high. (GCD) 50% Distillation Point is severely high. Visc @ 40°C is severely high.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.