



CARGILL CHUZHOU PLANT FP2

Customer: PTRHTF60027	System Information	Sample Information
SGS-CSTC 4/F 3RD BLDG NO.889 YI SHAN ROAD SHANGHAI, 200233 China Attn: Tobey Chen Tel: (861)391-7195596 E-Mail: tobey.chen@petrocanadalsp.com	System Volume: 3200 ltr Bulk Operating Temp: 572F / 300C Heating Source: Blanket: Fluid: PETRO CANADA PURITY FG HEAT TRANSFER FLUID Make:	Lab No: 02309999 Analyst: Tobey Chen Sample Date: 08/05/19 Received Date: 09/20/19 Completed: 11/05/19

Recommendation:

Comments: (GCD) 90% Distillation Point is severely high. (GCD) 10% Distillation Point is marginally high. (GCD) 50% Distillation Point is marginally high.

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
08/05/19	09/20/19	3m		410 / 210	21.6	35.2	0.872	0.085	755 / 402	846 / 452	942 / 506	0.00
Baseline Data				459 / 237		37.12	0.90		721 / 383	807 / 431	892 / 478	1.5



