




# KAONA FUTHER 1



Customer: PTRHTF60010	System Information	Sample Information
SYNLUBE INTERNATIONAL CO LTD 76/1 MOO.7 THACHIN MUANG SAMUTSAKHON, 74000 THAILAND Attn: Kittisak Suthithanakom Tel: 6(681)850-1907 E-Mail: kittisak@synlube.co.th	System Volume: 4400 ltr Bulk Operating Temp: 545F / 285C Heating Source: Blanket: Fluid: EASTMAN THERMINOL XP Make:	Lab No: 02312792 Analyst: Philip Riley Sample Date: 08/24/19 Received Date: 10/04/19 Completed: 10/18/19

Recommendation: Not a Petro Canada Fluid and do not have the fluid parameters to accurately diagnose sample.

Comments: (GCD) 10% Distillation Point is severely high. (GCD) 90% Distillation Point is severely high. Visc @ 40°C is abnormally high. COC Flash Point is marginally high.




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
08/24/19	10/04/19	10y	SUPPLY RETURN	430 / 221	0.00	32.7	0.655	0.049	728 / 387	829 / 443	947 / 508	0.79
01/12/19	01/23/19	1y	SUPPLY RETURN	320 / 160	11.1	27.8	0.45	0.011	665 / 352	778 / 415	865 / 463	6.03
06/23/18	07/13/18	9y	SUPPLY/RETURN	356 / 180	0.00	22.1	0.034	0.177	653 / 345	742 / 395	862 / 461	5.14
Baseline Data				360 / 182		23.7			630 / 332		781 / 416	





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
08/24/19	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	147	0
01/12/19	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	9	0
06/23/18	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Baseline Data			0	0						0			0	0					0				0	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



### Historical Comments

01/12/19	Please confirm if it is Therminol XP fluid. If it is the case, the fluid viscosity has been increased a lot from the last sample mainly due to the oil oxidation or the wrong oil top up. The fluid is also partially thermal cracked at the extremely high working temperature, so that the flash point is reduced. Please conduct the system venting to release the low boilers. Take one sample in 12 months to monitor the fluid conditions.
06/23/18	The current fluid has normal viscosity. Please monitor the fluid low flash point considering the high bulk oil temperature of 285C. Take one sample in 12 months to monitor the conditions. (GCD) 90% Distillation Point is high.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.