




## LN01 Filled Sealdown Loop Hot Oil System


| Customer: PTRHTF10141  | System Information  | Sample Information  |
|--|---|---|
| TAMKO BUILDING PRODUCTS<br>2300 35TH ST<br>TUSCALOOSA, AL 35401 USA<br>Attn: Greg Colburn<br>Tel: (205)752-3555<br>E-Mail: gregory_colburn@tamko.com | System Volume: 110 gal<br>Bulk Operating Temp: 350F / 177C<br>Heating Source:<br>Blanket:<br>Fluid: PETRO CANADA CALFLO HTF<br>Make: Heat Exchanger And T | Lab No: 02314439<br>Analyst: Jake Finn<br>Sample Date: 10/08/19<br>Received Date: 10/15/19<br>Completed: 11/08/19 |

Recommendation: Oil is suitable for continued use. Please resubmit sample in one year.

Comments: (GCD) 10% Distillation Point is marginally high. (GCD) 90% Distillation point has improved compared to previous sample.




| Sample Date   | Received Date | Fluid Age | Sample Location | Flash Point (COC) | Water (KF) | Viscosity (40°C) | Acid Number | Solids | GCD 10%   | GCD 50%   | GCD 90%   | GCD % < 335°C |
|---------------|---------------|-----------|-----------------|-------------------|------------|------------------|-------------|--------|-----------|-----------|-----------|---------------|
|               | mm/dd/yy      |           |                 | °F/°C             | ppm        | cSt              | mg/KOH/g    | %wt    | °F/°C     | °F/°C     | °F/°C     | %             |
| 10/08/19      | 10/15/19      | 0m        |                 | 424 / 218         | 9.2        | 35.2             | 0.132       | 0.081  | 741 / 394 | 830 / 443 | 924 / 496 | 0.00          |
| 01/08/19      | 01/17/19      | 13m       |                 | 435 / 224         | 10.1       | 35.5             | 0.065       | 0.077  | 687 / 364 | 782 / 417 | 880 / 471 | 2.53          |
| 06/28/18      | 07/09/18      | 0m        | PORT            | 446 / 230         | 13.8       | 35.4             | 0.07        | 0.023  | 724 / 385 | 809 / 432 | 910 / 488 | 0.50          |
| 02/15/18      | 02/22/18      | 9m        |                 | 432 / 222         | 5.4        | 35.5             | 0.03        | 0.017  | 713 / 379 | 808 / 431 | 900 / 482 | 1.39          |
| 11/01/17      | 01/18/18      | 6m        |                 | 432 / 222         | 14.9       | 31.1             | 0.112       | 0.275  | 634 / 334 | 658 / 348 | 778 / 414 | 10.41         |
| Baseline Data |               |           |                 | 448 / 231         |            | 35.20            | .1          |        | 712 / 378 | 810 / 432 | 910 / 488 | 1.75          |





| Sample Date          | Iron | Chromium | Nickel | Aluminum | Copper | Lead | Tin | Cadmium | Silver | Vanadium | Silicon | Sodium | Potassium | Titanium | Molybdenum | Antimony | Manganese | Lithium | Boron | Magnesium | Calcium | Barium | Phosphorus | Zinc |
|----------------------|------|----------|--------|----------|--------|------|-----|---------|--------|----------|---------|--------|-----------|----------|------------|----------|-----------|---------|-------|-----------|---------|--------|------------|------|
| 10/08/19             | 8    | 0        | 0      | 0        | 0      | 0    | 0   | 0       | 0      | 0        | 0       | 0      | 0         | 0        | 0          | 0        | 0         | 0       | 0     | 0         | 0       | 0      | 84         | 2    |
| 01/08/19             | 12   | 0        | 0      | 0        | 0      | 0    | 0   | 0       | 0      | 0        | 1       | 0      | 0         | 0        | 0          | 0        | 0         | 0       | 0     | 0         | 0       | 0      | 188        | 0    |
| 06/28/18             | 0    | 0        | 0      | 0        | 0      | 0    | 0   | 0       | 0      | 0        | 2       | 0      | 0         | 0        | 0          | 0        | 0         | 0       | 0     | 0         | 0       | 0      | 42         | 0    |
| 02/15/18             | 10   | 0        | 0      | 0        | 0      | 0    | 0   | 0       | 0      | 0        | 2       | 1      | 0         | 0        | 0          | 0        | 0         | 0       | 0     | 0         | 0       | 0      | 202        | 0    |
| 11/01/17             | 0    | 0        | 0      | 0        | 0      | 0    | 0   | 0       | 0      | 0        | 0       | 1      | 0         | 0        | 0          | 0        | 0         | 0       | 0     | 0         | 0       | 0      | 0          | 0    |
| <b>Baseline Data</b> |      |          | 0      | 0        |        |      |     |         |        | 0        |         | 0      | 0         |          |            |          |           | 0       |       |           |         |        | 280        |      |

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



### Historical Comments

|          |  |
|----------|--|
| 01/08/19 | 'Venting' system fluid may increase the distillation point values to desired levels. Fluid is suitable for continued use, please resubmit sample in December 2019.(GCD) 90% Distillation Point is abnormally low. (GCD) 90% Distillation Point is abnormally low.  |
| 06/28/18 | Fluid is suitable for continued use. Please re-submit next sample in June 2019Some very light debris was noticed. Change any system filters regularly or tighten up the micron levels for a cleaner fluid. This fluid can be polished using a 2-stage kidney loop system safely during any shutdown periods.   |
| 02/15/18 | Fluid is suitable for continued use.Improvements over the previous sample submitted 3.5 months earlier are noticeable. There was an increase in visible 'debris' although the color of the fluid is much clearer then before. If possible, filtering this fluid will assist in maintaining cleanliness or changing any system filters.   |
| 11/01/17 | This sample has significantly changed negatively since the previous sample 1 month prior. This fluid may be a candidate for a drain, flush and fill with virgin Calflo HTF only because of the rate of change noticed between samples.Pentane Insolubles have increased from .02 to .2 which is a big leap in the 'solids' found in the oil. Oil oxidation may be occurring as witnessed in the severe increase in the distillation curve <335oC (GCD) 50% Distillation Point is severely low. (GCD) 90% Distillation Point is severely low. (GCD) 10% Distillation Point is abnormally low. (GCD) % < 335°C is marginally high. |

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.