




LINE 2 FILLER HEATER SYSTEM



| Customer: PTRHTF10069 | System Information | Sample Information |
|--|--|---|
| CERTAINEED - SAINT GOBAIN 3303 EAST 4TH AVENUE SHAKOPEE, MN 55379 USA Attn: Patrick Wallace Tel: E-Mail: patrick.wallace@saint-gobain.com | System Volume: 5670 gal Bulk Operating Temp: 428F / 220C Heating Source: Blanket: Fluid: PETRO CANADA CALFLO AF Make: | Lab No: 02315478 Analyst: Gaston Arseneault Sample Date: 09/24/19 Received Date: 10/21/19 Completed: 11/12/19 Gaston Arseneault gaston.arseneault@hollyfrontier.com |

Recommendation: We can't explain why the viscosity remained identical but the flash point dropped by 30C. Contamination by asphalt, water or other elements is insignificant or non-detectable. No actions needed at this time. Re-sample at next scheduled interval.

Comments: COC Flash Point is marginally low.




| Sample Date | Received Date | Fluid Age | Sample Location | Flash Point (COC) | Water (KF) | Viscosity (40°C) | Acid Number | Solids | GCD 10% | GCD 50% | GCD 90% | GCD % < 335°C |
|---------------|---------------|-----------|---------------------|-------------------|------------|------------------|-------------|--------|-----------|-----------|-----------|---------------|
| | mm/dd/yy | | | °F/°C | ppm | cSt | mg/KOH/g | %wt | °F/°C | °F/°C | °F/°C | % |
| 09/24/19 | 10/21/19 | 0.0y | MAIN SYSTEM FLOW | 363 / 184 | 7.1 | 26.4 | 0.032 | 0.116 | 699 / 371 | 794 / 424 | 895 / 479 | 1.69 |
| 09/30/18 | 10/10/18 | 0.0y | | 417 / 214 | 0.00 | 26.1 | 0.059 | 0.027 | 687 / 364 | 778 / 415 | 874 / 468 | 1.90 |
| 09/03/17 | 09/12/17 | 4.0y | MAIN SYSTEM FLOW | 374 / 190 | 0.00 | 20.7 | 0.027 | 0.042 | 682 / 361 | 785 / 419 | 891 / 477 | 3.93 |
| 05/14/16 | 05/24/16 | 0.0y | MAIN SYSTEM FLOW | 331 / 166 | 2.3 | 24.7 | 0.066 | 0.080 | 665 / 352 | 773 / 411 | 866 / 463 | 6.19 |
| 06/06/14 | 06/17/14 | 0.0y | MAIN FLOW NEAR PUMP | 370 / 188 | 3.2 | 23.2 | 0.02 | 0.034 | 669 / 354 | 783 / 417 | 888 / 475 | 6.18 |
| Baseline Data | | | | 435 / 224 | | 32.7 | 0.03 | | 693 / 367 | 790 / 421 | 887 / 475 | 2.5 |





| Sample Date | Iron | Chromium | Nickel | Aluminum | Copper | Lead | Tin | Cadmium | Silver | Vanadium | Silicon | Sodium | Potassium | Titanium | Molybdenum | Antimony | Manganese | Lithium | Boron | Magnesium | Calcium | Barium | Phosphorus | Zinc | |
|----------------------|------|----------|--------|----------|--------|------|-----|---------|--------|----------|---------|--------|-----------|----------|------------|----------|-----------|---------|-------|-----------|---------|--------|------------|------|---|
| 09/24/19 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 61 | 0 | |
| 09/30/18 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 48 | 0 |
| 09/03/17 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 49 | 0 |
| 05/14/16 | 7 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 42 | 0 |
| 06/06/14 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 17 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 14 | 0 | 69 | 0 | |
| Baseline Data | | | 0 | 0 | | | | | | 0 | | 0 | 0 | | | | | 0 | | | | | 270 | | |

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments

| | |
|----------|--|
| 09/30/18 | Flash point remains strong even if the viscosity hovers around 15% lower than fresh oil. Results appear to remain stable from year to year. Re-sample at next scheduled interval. No trace of contamination by asphalt or the elements or fluid degradation. |
| 09/03/17 | We can not explain why the oil viscosity dropped 20% yet the flash point increased by dozens of degrees. Anywho, no immediate action seems required at this time. Re-sample at next normal interval. Visc @ 40°C is abnormally low. COC Flash Point is marginally low. |
| 05/14/16 | COC Flash Point is abnormally low. GCD % at 335C is marginally high at 6.19% and should consider venting. Other properties look good. Resample next interval to monitor. |
| 06/06/14 | The oil carries a certain amount of low boilers. We recommend to vent them out and replace lost volume with fresh oil addition. COC Flash Point is marginally low. |

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.