


VTA HOT OIL PUMP


Customer: PTRHTF10004	System Information	Sample Information
ADM VITAMIN E PLANT	System Volume: 1800 gal	Lab No: 02321734
3700 EAST DIVISION STREET	Bulk Operating Temp: 650F / 343C	Analyst: Joe Goecke
DECATUR, IL 62526 USA	Heating Source:	Sample Date: 11/13/19
Attn: Rick Cluck	Blanket:	Received Date: 11/21/19
Tel: (217)451-7770	Fluid: PETRO CANADA PURITY FG HEAT TRANSFER FLUID	Completed: 11/27/19
E-Mail: ricky.cluck@adm.com	Make: AMERICAN HEATING	Joe Goecke
		Joe.goecke@petrocanadalsp.com

Recommendation: Viscosity is still low and flash point has decreased I suggest planning a change or partial change to get the system in better condition within the next 45 days.

Comments: (GCD) 10% Distillation Point is severely low. COC Flash Point is severely low. Visc @ 40°C is severely low. (GCD) % < 335°C is abnormally high.

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
11/13/19	11/21/19	0y	B4 HOT OIL PUMP	226 / 108	4.0	16.5	0.059	0.046	600 / 315	780 / 415	898 / 481	12.03
05/14/19	05/22/19	0y	B3	266 / 130	9.5	12.2	0.044	0.050	567 / 297	783 / 417	904 / 485	14.36
10/11/18	10/18/18	0y		286 / 141	10.0	24.6	0.03	0.036	677 / 358	802 / 428	908 / 487	6.37
09/20/18	09/27/18	2у		232 / 111	8.6	17.7	0.01	0.021	503 / 262	775 / 413	882 / 472	17.77
03/13/18	03/21/18	0y		264 / 129	6.2	20.0	0.042	0.049	535 / 280	761 / 405	880 / 471	19.53





Historical Comments

05/14/19	This system is extremely low on viscosity at 12.2 cSt. Flash point is over 100 degrees C less than a fresh charge and the low boilers are over 14%. I recommend planning a change of this oil soon since venting is currently not an option. Heat transfer ability and safety are main concerns. (GCD) 10% Distillation Point is severely low. COC Flash Point is severely low. Visc @ 40°C is severely low. (GCD) % < 335°C is abnormally high.
10/11/18	System much better. Flash point still a little low, but 30 Degrees C higher than before. GCD points all looking better. Continue to use and resample in 60 days. COC Flash Point is severely low.
09/20/18	Viscosity is half of new oil, Flash point is extremely low, low boilers are very high at 17.8% 10% distillation point also very low at 261.8C. This heat transfer efficacy of this oil is going to suffer. Oil needs to be changed ASAP to improve safety of operation. (GCD) % < 335°C is severely high. (GCD) 10% Distillation Point is severely low. COC Flash Point is severely low. Visc @ 40°C is severely low.
03/13/18	System continues to be dangerously low on flash point and getting higher with low boilers or light ends creating a concern. System should be changed ASAP. Viscosity also critically low. (GCD) % < 335°C is severely high. (GCD) 10% Distillation Point is severely low. COC Flash Point is severely low. Visc @ 40°C is severely low.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.