

## **RRRTANK**

## Customer: PTRHTF30107

D-CONSTRUCTION 16805 QUARRY RD MORRIS, IL 60450 USA

Attn: Chris Lenzie Tel: (815)405-6831

E-Mail: clenzie@sandenoinc.com

## System Information

System Volume: 2000 gal

Bulk Operating Temp: Not Specified

Heating Source:

Blanket:

Fluid: HEAT TRANSFER FLUID ISO 15

Make:


## Sample Information

Lab No: 02322038 Analyst: Yvette Trzcinski Sample Date: 11/21/19 Received Date: 11/22/19 Completed: 12/03/19

Recommendation: The fluid name is not listed on this sample and does not match the viscosity of the Pritherm NF-1 that customer mentioned was the fluid in use- need to verify what fluid is in the system. This fluid is experiencing thermal degradation - 90% distillation point is low, but low boilers and solids are within acceptable limits as well as the Acid number - resample in 6 months

Comments: (GCD) 90% Distillation Point is abnormally low.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.