

# **HEATTRANSFER- SUCTION PIPING**

# Customer: PTRHTF20033

Moose Jaw Refinery 641 Manitoba St. E, Box 2000 Moose Jaw, SK S6H 6E3 Canada

Attn: GILBERT GRIFFIN Tel: (603)691-7823

E-Mail: ggriffin@mjrefinery.com

# System Information

System Volume: 1308 gal

Bulk Operating Temp: 320F / 160C

Heating Source:

Blanket:

Fluid: PETRO CANADA PETRO-THERM

Make: CHILDERS


#### Sample Information


Lab No: 02322474

Analyst: Kevin McDermott Sample Date: 11/18/19 Received Date: 11/25/19 Completed: 12/19/19


Recommendation: The Acid Number (AN) is very high. This combined with gradual viscosity increase and solids content indicate fluid degradation due to oxidation. Consideration should be given to a full or partial changeout of the fluid. Once oxidation begins it can worsen exponentially resulting in system fouling with deposits. Suggest submitting another sample soon to see if degradation is progressing.

#### Comments:






Report ID: [02322474] (Generated: 12/19/2019 17:37:02) - Page 1 - Copyright 2019 Wearcheck Inc. All Rights Reserved.



Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]

0

Baseline Data



Historical Comments	
10/17/17	The current fluid has normal viscosity, flash point, and GCD distillation points. The TAN reading and the solids content are higher than normal because of the minor oxidation. However, the fluid is still suitable for use. Please take one sample in 8 months to monitor the conditions.
01/26/17	The current fluid has normal viscosity, flash point, TAN and GCD distillation points. The solids content is high because of the minor oxidation. Please continue to run the fluid and take one sample in 8 months to monitor the conditions.
08/25/16	The current fluid has adequate viscosity, distillation points and the flash point. The water level and the solid content are all low. TAN is higher than the fresh fluid, meaning the fluid has minor oxidation, but still suitable for further use. Please take one sample in one year to monitor the conditions.
09/30/14	The current fluid is oxidized because of the high TAN and high solid contents. The abnormally high viscosity also reduce the system efficiency. Please consider the oil change soon. Please investigate the water contamination and verify the unit age / oil age.Acid Number (AN) is severely high. Visc @ 40°C is abnormally high. Insoluble/solid level is severely high. Water contamination levels are marginally high.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.