




## WANSON BH/INC 1200



Customer: PTRHTF40127	System Information	Sample Information
Dalco Foods B.V Everdenberg 50 Oosterhout, 4902TT Netherlands Attn: Wilbert Snijers Tel: E-Mail: w.snijers@klt.nl	System Volume: 4200 gal Bulk Operating Temp: 518F / 270C Heating Source: Blanket: Fluid: PETRO CANADA PURITY FG HEAT TRANSFER FLUID Make: WANSON	Lab No: 02322868 Analyst: Philip Riley Sample Date: 11/14/19 Received Date: 11/26/19 Completed: 12/10/19

Recommendation: Sample continues to deteriorate. How long has the system been running as there are inconsistent values of age input against previous samples. Viscosity has decreased and evidence of cracking of the oil (shape of curve), also reducing flash point and 10% distillation. Please try safe venting and check for recovery. Otherwise, operating at 270C is well above the current flash point which has reduced down to 170C. Recommended venting and re-sample to check recovery. If continues to deteriorate look towards a change. Please, again, clarify the actual operating time as the sequence does not make sense in previous samples

Comments: (GCD) 10% Distillation Point is severely low. COC Flash Point is severely low. (GCD) % < 335°C is marginally high.




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
11/14/19	11/26/19	2y		338 / 170	10.4	25.9	0.284	0.106	616 / 325	780 / 416	883 / 473	10.68
07/01/19	07/09/19	7y		338 / 170	25.6	27.0	0.245	0.079	640 / 338	782 / 417	886 / 475	9.18
02/28/19	03/06/19	9y		349 / 176	18.2	28.6	0.359	0.111	684 / 362	791 / 422	887 / 475	5.18
12/03/18	12/11/18	0y		417 / 214	17.5	30.0	0.414	0.067	702 / 372	801 / 427	897 / 481	3.65
08/08/18	08/14/18	3y		406 / 208	36.7	32.6	0.38	0.048	713 / 378	801 / 427	895 / 480	1.88
Baseline Data				459 / 237		37.12	0.90		721 / 383	807 / 431	892 / 478	1.5





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
11/14/19	3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	30	0
07/01/19	4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	21	0
02/28/19	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	19	0
12/03/18	3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	21	0
08/08/18	3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	26	0
<b>Baseline Data</b>			0	0						0			0	0					0				230	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments	
07/01/19	FLuid age look sot have reduced? Signs of low flash point and steadily reducing viscosity if trending correct with fluid ages. If the fluid can be safely vented it may recover the flash point, otherwise re-sample in 6 months to check on the fluid degradation COC Flash Point is severely low. (GCD) % < 335°C is marginally high.
02/28/19	Flash Point (COC) is very low and off specification. Recommend venting the system if it is safe to do so and resample after venting to see how the oil charge has recovered flash point. COC Flash Point is severely low.
12/03/18	FLuid looks in good condition with respect to expected parameters. Some more clarity required on the unit age, time on oil etc as this is not consistent with previous samples. Based on result set the fluid is fit for further use and should be sampled at the next scheduled interval
08/08/18	Flash Point marginally low, and evidence of light molecules in the GCD. All tests within allowable limits and fluid fit for further use

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.