



Customer: PTRHTF20191	System Information	Sample Information			
STRATH RESOURCES	System Volume: 35000 ltr	Lab No: 02327610			
66-8-62-3W6	Bulk Operating Temp: 266F / 130C	Analyst: Clinton Buhler			
GRANDE PRAIRIE, AB Canada	Heating Source:	Sample Date: 11/28/19			
Attn: Rob Bruce	Blanket:	Received Date: 12/17/19			
Tel: (403)396-0908	Fluid: PETRO CANADA PETRO-THERM	Completed: 01/06/20			
E-Mail: rbruce@strathresources.com	Make: RUSHTON				

Recommendation: Sample results would indicate that the fluid is suitable for continued service.it is understood that blanket gas is not currently being used. Please ensure blanket gas is operational to protect the fluid from air that can cause oxidation and subsequent acid formation. 2-3 psi is sufficient to protect the fluid.As part of good maintenance practice, regular venting of the expansion tank can keep low boiling vapors at low concentrations. Please re-sample in 6 months.

Comments:

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
11/28/19	12/17/19	6m	TANK	442 / 228	291.0	33.6	0.045	0.200	699 / 371	793 / 423	902 / 484	1.35





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.