



PECO LSD 8-11-47-16W5


Customer: PTRHTF20233	System Information	Sample Information
CANLIN ENERGY	System Volume: 7000 Itr	Lab No: 02327612
8-11-47-16W5	Bulk Operating Temp: 401F / 205C	Analyst: Terry Veenstra
EDSON, AB Canada	Heating Source:	Sample Date: 12/08/19
Attn: Dana Erickson	Blanket:	Received Date: 12/17/19
Tel: (780)517-7585	Fluid: PETRO CANADA PETRO-THERM	Completed: 01/07/20
E-Mail:	Make: ALCO	
dana.erickson@canlinenergy.com		

Recommendation: Sample contains a significant amount of water. Please ensure the sample is taken from a circulated area and that the sample line has been purged sufficiently. Too much water in the system can be a safety concern due to risk of boiler over. Results indicate that the sample may not be representative. Please resample and resubmit ASAP.

Comments: Water contamination levels are severely high. ppm Water contamination levels are severely high. ppm Water contamination levels are severely high.. Pentane Insolubles levels are abnormally high. Acid Number (AN) is abnormally high.







Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.

Report ID: [02327612] (Generated: 01/07/2020 11:37:22) - Page 2 - Copyright 2020 Wearcheck Inc. All Rights Reserved.