

YONG SHUN PU U-5

Customer: PTRHTF60007

CANADIAN RESOURCES INC 2F 71 CHONG CHING NORTH ROAD S

C 3

TAIPEI, TAIWAN, PROVINC

Attn: HUGO CHENG Tel: (886)225-853509

E-Mail: hugo@cdnresources.ca

System Information

System Volume: 6765 ltr

Bulk Operating Temp: 419F / 215C

Heating Source:

Blanket:

Fluid: PETRO CANADA CALFLO HTF

Make:

Sample Information

Lab No: 02329283 Analyst: Philip Riley Sample Date: 12/18/19 Received Date: 12/30/19 Completed: 01/20/20


Philip Riley

philip.riley@petrocanadalsp.com

Recommendation: The sample has recovered from the previous sample, with the exception of Acid Number which has worsened. As with previous samples there is no mention of time running so makes it difficult to properly rate, or was this even a partial changeover? Please re-sample in 6 months and ensure time of oil in system is quoted to ensure a thorough diagnosis


Comments: Acid Number (AN) is abnormally high.







Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments	
02/23/18	The current fluid has high viscosity, TAN and solid contents because of the moderate oxidation. Please take one sample in 6 months to monitor the conditions. The fluid hours are not reported, which definitely limit our interpretation. Please inform Yutong Gao at Petro-Canada for the detailed fluid hours.
11/29/16	The current fluid has adequate viscosity, flash point, acid number and distillation points. However, the water content is quite high, please double check the reason of the water contamination. The higher solid is because of the moderate fluid oxidation. The fluid is OK for continual run and please take a sample in 12 months to monitor the conditions.
08/17/15	The current fluid has normal viscosity, GCD, solid and water. The higher TAN reading indicates a mild oxidation, but this fluid is suitable for further use. Please take one sample in one year to monitor the conditions. Please remember to provide the total fluid working hours when you send the future samples. Acid Number (AN) is abnormally high.
11/24/14	The current fluid has moderate oxidation and mild thermal cracking, but it is still suitable for the further use. Please take one sample in 3 months to monitor the conditions. Solid levels are severely high. (GCD) 10% Distillation Point is marginally low.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.