

## YONG SHUN PU U-4

## Customer: PTRHTF60007

CANADIAN RESOURCES INC 2F 71 CHONG CHING NORTH ROAD S

C 3

TAIPEI, TAIWAN, PROVINC

Attn: HUGO CHENG Tel: (886)225-853509

E-Mail: hugo@cdnresources.ca

## System Information

System Volume: 5330 ltr

Bulk Operating Temp: 419F / 215C

Heating Source:

Blanket:

Fluid: PETRO CANADA CALFLO HTF

Make:

## Sample Information

Lab No: 02329286 Analyst: Philip Riley Sample Date: 12/18/19 Received Date: 12/30/19 Completed: 01/20/20


Philip Riley

philip.riley@petrocanadalsp.com

Recommendation: All key parameters within normal limits except for the Acid Number that has recovered slightly from the previous sample. Has there been any maintenance and change over on the fluid? There are no fluid hours/moths listed so difficult to tell, please ensure these are included on all future samples. Please re-sample in 6 months


Comments: Acid Number (AN) is abnormally high.







Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments	
02/23/18	The current fluid has high viscosity, TAN and solid contents because of the severe oxidation. Please take one sample in 6 months to monitor the conditions. The fluid hours are not reported, which definitely limit our interpretation. Please inform Yutong Gao at Petro-Canada for the detailed fluid hours.
11/29/16	Insufficient sample was received to conduct all the routine laboratory tests. The available test data show the current fluid has the moderate oxidation. But the fluid is OK for continual run and please take a sample in 12 months to monitor the conditions. Please remember to take about 600~700ml sample in the future.
08/17/15	The current fluid has normal viscosity, GCD and water. The higher TAN and Solid reading indicate a mild oxidation, but this fluid is suitable for further use. Please take one sample in one year to monitor the conditions. Please remember to provide the total fluid working hours when you send the future samples. Pentane Insolubles levels are abnormally high. Acid Number (AN) is abnormally high.
11/24/14	The current fluid has normal viscosity, TAN, GCD points and flash point. The high solid level might be due to the moderate oxidation. Normally, we need to know the fluid working hours to provide the comments, please take one sample in 6 months to monitor the conditions and provide the fluid working hours at the same time. Solid level is abnormally high.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.