


RIGHTPOINTE


Customer: PTRHTF10203	System Information	Sample Information			
LEAHY-WOLF COMPANY	System Volume: 3000 gal	Lab No: 02329485			
1724 W ARMITAGE COURT	Bulk Operating Temp: 400F / 204C	Analyst: Yvette Trzcinski			
SUITE A	Heating Source:	Sample Date: 12/23/19			
ADDISON, IL 60101 USA	Blanket:	Received Date: 01/02/20			
Attn: TERRY LONG	Fluid: PETRO CANADA PETRO-THERM	Completed: 01/03/20			
Tel:	Make: GEI				
E-Mail: terrylong@leahywolf.com					

Recommendation: The Acid number is high for a system this size which is an indicator that there is fluid oxidation occurring which leads to acid formation and fluid degradation. That degradation creates the potential for fouling and build up in the system, causing issues with system performance and efficiency. Recommend evaluating the system performance to understand extent of fouling and potential re sample of the fluid

Comments: Acid Number (AN) is abnormally high.

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
12/23/19	01/02/20	15y		414 / 212	11.4	36.5		0.219	695 / 368	791 / 422	901 / 483	2.05
Deceline Dete			400 / 000		24.0	0.02		700 / 200	017/400	000 / 490	1.00	





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.