

## **VAPORIZER #7**

Customer: PTRHTF10092	System Information	Sample Information
REC GROUP	System Volume: 100 gal	Lab No: 02332064
119410 RICK JONES WAY	Bulk Operating Temp: 250F / 121C	Analyst: Ron LeBlanc
BUTTE (SILVER BOW), MT 59750 USA	Heating Source:	Sample Date: 01/01/20
Attn: ZACK KELLY	Blanket:	Received Date: 01/15/20
Tel: (406)496-9717	Fluid: PETRO CANADA CALFLO LT	Completed: 01/21/20
E-Mail: zack.kelly@recgroup.com	Make:	

Recommendation: Sample appears normal. Sample at next scheduled interval. Be sure to purge oil at sample point before filling container.

Comments: (GCD) % < 335°C is marginally high.

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
01/01/20	01/15/20	7y		374 / 190	9.9	9.6	0.017	0.096	611 / 322	647 / 342	739 / 393	43.27
11/18/17	12/04/17	5у		370 / 188	3.6	9.4	0.019	0.021	619 / 326	689 / 365	842 / 450	23.02
03/04/17	03/15/17	5у	SST #7 REBOILER	363 / 184	<mark>364.3</mark>	9.0	0.028	0.013	616 / 324	674 / 357	791 / 421	30.01
02/15/12	02/22/12	0y	BOTTOM DRAIN	441 / 227	40	31.5	0.11	0.005	689 / 365	795 / 424	891 / 477	3.766
01/24/12	01/31/12		NA	433 / 223	21	36.7	1.36	0.219	699 / 370	787 / 420	882 / 472	0.789





Elemental anaysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



## **Historical Comments**

11/18/17	(GCD) 90% Distillation Point is severely high. (GCD) 50% Distillation Point is abnormally high. It appears there is a process leak as the silicon has doubled in comparison to last time. (GCD) 90% Distillation Point is severely high. (GCD) 50% Distillation Point is abnormally high.
03/04/17	Water level is high. Viscosity has dropped significantly. Determine where water has entered system. Resample in one month to determine if this sample was taken improperly or if the sample reflects actual condition of the oil. Purge oil at collection point to get a respective sample. Water contamination levels are marginally high. ppm Water contamination levels are marginally high. (GCD) 90% Distillation Point is severely high. (GCD) 50% Distillation Point is marginally high.
02/15/12	The oil appears to be in great shape, which is expected since it's after a full cleaning of the Vaporizer system. We see the TAN is higher than fresh oil and we observe some Calcium and Zinc which are not part of the Calflo AF. We are suspecting they might come from the cleaning solution or flushing oil used, which may have been a AW hydraulic oil or something with detergents in it. Let's re-sample in 6 months time to monitor the oil condition and degradation rate in those Vaporizer systems.
01/24/12	The oil appear to be oxidized. The Total Acid Number is elevated at 1.4. The viscosity is also higher than fresh oil which is also a sign of oxidation, even though the additives seem to be present at healthy levels. Which bring the question if the acid number is due to some acid contamination, maybe through a chlorosilane leak, but the silicon is very low at 6 ppm.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.