

[Pembina Kakwa 8-13-63-5W6] Phase 1 Heat Medium

Customer: PTRHTF20062

Pembina Gas Services

GRANDE PRAIRIE, AB T8V 7K2 Canada

Attn: Nicolas Brooks Tel: (403)874-8047

0.

0.0

E-Mail: nbrooks@pembina.com

System Information

System Volume: 0 gal

Bulk Operating Temp: 400F / 204C

Heating Source:

Blanket:

Fluid: PETRO CANADA CALFLO AF

Make: PETRO-TECH

Sample Information

Lab No: 02335519 Analyst: Clinton Buhler Sample Date: 01/07/20 Received Date: 02/03/20 Completed: 02/19/20

Clinton Buhler

195 190

185

180


Jan 7/20

Jan 7/20

Clinton.Buhler@PetroCanadaLSP.com

Recommendation: Sample results indicate excess water in the system. This may be from contamination but can also indicate a sample being drawn for a static low spot that may not have been purged before drawing the sample. Excess water needs to be carefully vented from the system as it can pose a risk of boil over. Water can also increase the rate of fluid oxidation and subsequent increase in Acid Number. Fluid is suitable for further service otherwise. Please vent system of steam and then re-sample in 3 months. Be cognizant of proper sampling techniquethoroughly purge out sample valve and piping to ensure sample is representative of system condition.

Comments: Water contamination levels are severely high. Water contamination levels are severely high.. ppm Water contamination levels are severely high.



Jan31/17

25


20

Jan 22/19

Jan 31/1



Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments Sample results indicate the fluid is suitable for continued service. Water content and acid number has increased- this can be associated with not fully purging sampling valves and related piping. Percent boil-off has increased from 1.47 to 4.73. This can be related to high blanket gas pressure or thermal degradation. Consider venting of expansion tank to reduce low boiling vapor molecules, but if high blanket gas pressure is required for positive pump suction head, venting may need to happen during an outage. Re-sample in 12 months Flash point is marginally low. Otherwise, sample results indicate that fluid is suitable for continued service. Please re-sample in 12 months. COC Flash Point is marginally low. This sample indicates the oil is in good condition and is suitable for continued use. Resample in 6 months. Oil looks fine and suitable for continued use.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.