



Customer: PTRHTF20236	System Information	Sample Information
Semcams MIdstream	System Volume: 55000 ltr	Lab No: 02335523
11-21-66-3w6	Bulk Operating Temp: 392F / 200C	Analyst: Clinton Buhler
Grande Prairie, AB Canada	Heating Source:	Sample Date: 11/21/19
Attn: Don Dempensy	Blanket:	Received Date: 02/03/20
Tel: (780)208-5089	Fluid: PETRO CANADA PETRO-THERM	Completed: 02/20/20
E-Mail: ddempsey@semgroup.com	Make: HEATEC	Clinton Buhler
		Clinton.Buhler@PetroCanadaLSP.com

Recommendation: Sample results indicate that there is excess water in the system. This may be related to initial construction and commissioning or may also be related to where the sample could have been drawn from (stagnant low lying area where water can collect) and/or perhaps the sample valve and piping was not purged out thoroughly before taking the sample. Water vapor should be safely and thoroughly vented from the system expansion tank. Check for water at low spots in the system. Once this is completed, please re-sample in ~3-6 months, being cognizant to thoroughly purge the sample valve and piping the sample.

Comments: Water contamination levels are abnormally high

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
11/21/19	02/03/20	1m	PUMP SUCTION	430 / 221	814.9	35.2		0.050	736 / 391	814 / 435	916 / 491	0.00





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.

Report ID: [02335523] (Generated: 02/20/2020 11:21:26) - Page 2 - Copyright 2020 Wearcheck Inc. All Rights Reserved.