



TOURMA LINE H55002

Customer: PTRHTF20039

BRENNTAG CANADA INC 3124-54TH AVENUE SE CALGARY, AB T2C 0A8 Canada

Attn: Matthew Kryska

Tel:

E-Mail: mkryska@brenntag.ca

System Information

System Volume: 8000 ltr

Bulk Operating Temp: 446F / 230C

Heating Source:

Blanket:

Fluid: PETRO CANADA PETRO-THERM

Make:

Sample Information


Lab No: 02345231 Analyst: Terry Veenstra Sample Date: 02/16/20 Received Date: 03/23/20 Completed: 03/26/20


Terry Veenstra

terry.veenstra@petrocanadalsp.com

Recommendation: Distillation (GCD) at 10% and 90% are marginally high. Otherwise fluid seems to be in good condition. Verify operating temperature and volume of system as all 3 systems were reported the same. Cannot do trend analysis without history. Resample in 6 months.

Comments: (GCD) 10% Distillation Point is marginally high. (GCD) 90% Distillation Point is marginally high.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.