




FILLER HEATER


Customer: PTRHTF10068	System Information	Sample Information
Certainteed - Saint Gobain 1077 PLEASANT ST NORWOOD, MA 02062 USA Attn: David Fletcher Tel: (781)551-0656 E-Mail: david.r.fletcher@saint-gobain.com	System Volume: 2200 gal Bulk Operating Temp: 550F / 288C Heating Source: Blanket: Fluid: PETRO CANADA CALFLO AF Make: PERFORMANCE HEATING	Lab No: 02353749 Analyst: Doug Vrooman Sample Date: 05/04/20 Received Date: 05/13/20 Completed: 05/21/20 Doug Vrooman douglas.vrooman@petrocanadalsp.com

Recommendation: The sample results for the Filler Heater have shown slight improvements with Flash point from 175 to 198. Low boilers GCD 10% 362.9 as well as GCD 90% 483.8 have decrease slightly. Acid number has also decrease from .116 to .06. Continue to monitor at planned intervals.

Comments:




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
05/04/20	05/13/20	12m	DUPLEX	388 / 198	19.2	26.4	0.06	0.093	685 / 363	794 / 423	903 / 484	4.17
09/20/19	10/01/19	7m	DUPLEX PUMPS	347 / 175	41.2	27.8	0.116	0.069	704 / 373	811 / 433	920 / 493	2.35
05/29/19	06/19/19	0m	DUPLEX PUMP	403 / 206	23.8	30.7	0.207	0.155	693 / 367	792 / 422	901 / 483	1.22
Baseline Data				435 / 224		32.7	0.03		693 / 367	790 / 421	887 / 475	2.5





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc	
05/04/20	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	21	0	
09/20/19	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	27	0
05/29/19	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	26	0
Baseline Data			0	0						0			0	0					0					270	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments	
09/20/19	This new Higher Temp system is effecting HTF condition. We are noticing that the viscosity has dropped to 27.8 cSt @ 40C as well as COC Flash point which has dropped to 175. We recommend Venting (boil-off), as soon as possible. We would also recommend venting more frequently and adding fresh (make-up) fluid more frequently to assist with fluid condition. There is no asphalt contamination reported at this time. (GCD) 90% Distillation Point is abnormally high. COC Flash Point is abnormally low.
05/29/19	We understand there was some issue with the nitrogen blanket on this new system hence the slight rise in Acid Number. Other properties look normal. Re-sample in 6 months to closely monitor this new system.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.