RFO3 HOT OIL BOILER #2

Customer: PTRHTF10057

PROPEX RINGGOLD PLANT 428 ROLLINS INDUSTRIAL BLVD RINGGOLD, GA 30736 USA Attn: STEWART DOMAINGUE

Tel: (423)553-3843

E-Mail:

stewart.domaingue@propexglobal.com

System Information
System Volume: 30 gal

Bulk Operating Temp: 400F / 204C

Heating Source:

Blanket:

Fluid: PETRO CANADA CALFLO AF

Make:

Sample Information

Lab No: 02358526 Analyst: Jake Finn Sample Date: 05/22/20 Received Date: 06/09/20 Completed: 06/23/20


Jake Finn

jake.finn@petrocanadalsp.com

Recommendation: This fluid is in severe condition and is not suitable for continued use. It is recommended that the system is drained and re-filled with premium, virgin Petro-Canada Calflo AF.

Comments: Copper and iron ppm levels are severe. Water contamination levels are severely high. (GCD) 10% Distillation Point is severely high. Visc @ 40°C is severely low. Acid Number (AN) is abnormally high.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.