




## VAPOR POWER


Customer: PTRHTF30020	System Information	Sample Information
IKO INDUSTRIES HAWKESBURY 1451 SPENCE ROAD HI-PARTS-HAWK YARD HAWKESBURY, ON K6A 3T4 Canada Attn: Roy Paquette Tel: (613)632-8581 E-Mail: roy.paquette@iko.com	System Volume: 600 gal Bulk Operating Temp: 500F / 260C Heating Source: Blanket: Fluid: PETRO CANADA PETRO-THERM Make: VAPOR POWER	Lab No: 02359041 Analyst: Pierre Castagne Sample Date: 06/02/20 Received Date: 06/11/20 Completed: 06/22/20 Pierre Castagne pierre.castagne@petrocanadalsp.com

Recommendation: Ok for continuous use

Comments:




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
06/02/20	06/11/20	3y	HOT OIL BOILER	457 / 236	12.3	34.6	0.09	0.119	723 / 384	816 / 436	915 / 491	1.30
07/12/19	07/18/19	1y		396 / 202	23.2	35.3	0.115	0.164	707 / 375	804 / 429	915 / 491	0.84
10/15/18	10/18/18	3y		406 / 208	16.2	35.4	0.03	0.040	726 / 385	805 / 429	909 / 487	0.00
02/15/18	02/22/18	243y		406 / 208	5.3	35.5	0.03	0.038	705 / 374	809 / 432	917 / 492	2.68
05/04/17	05/11/17	1y	HOT OIL BOILER	410 / 210	18.9	36.5	0.02	0.069	712 / 378	814 / 434	937 / 503	1.31
Baseline Data				433 / 223		34.2	0.03		720 / 382	817 / 436	900 / 482	1.00





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
06/02/20	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	6	0	0	0
07/12/19	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	13	0	0	0
10/15/18	6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	4	0	0	0
02/15/18	6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	6	0	0	0
05/04/17	11	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	18	0	0	0
<b>Baseline Data</b>			0	0						0			0	0					0				0	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



**Historical Comments**

07/12/19	You have some carbon buildup (GCD @90%) is high.
10/15/18	Le fluide caloporteur est normal
02/15/18	High boilers (GCD @ 90%) increase viscosity, as a result carbon deposit settle in low flow/disturbance areas and foul heat exchange surfaces. Looking at the curve, it appears that a low viscosity oil mixture has occurred.
05/04/17	The sample has trace of Vanadium, the Low boilers GCD @10% are within specification (this could be the result of topping-up the oil) although the flash point is lower than the Petro-Therm oil specification (210°C versus 225°C specification),this suggests some oil craking is taking place. The High boilers GCD @ 90% are higher than the specification; this normally causes the viscosity of the oil to increase and carbon deposits. (GCD) 90% Distillation Point is severely high.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.