



Customer: PTRHTF10141	System Information	Sample Information
TAMKO BUILDING PRODUCTS	System Volume: 110 gal	Lab No: 02362007
2300 35TH ST	Bulk Operating Temp: 350F / 177C	Analyst: Jake Finn
TUSCALOOSA, AL 35401 USA	Heating Source:	Sample Date: 06/10/20
Attn: Greg Colburn	Blanket:	Received Date: 06/29/20
Tel: (205)752-3555	Fluid: PETRO CANADA CALFLO HTF	Completed: 07/02/20
E-Mail: gregory_colburn@tamko.com	Make: Heat Exchanger And T	Jake Finn
		jake.finn@petrocanadalsp.com

Recommendation: Fluid is suitable for continued use. Please resubmit for testing in one year.

Comments: Very light white metal and debris noted by lab. Consider checking system filters and changing them if necessary.

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
06/10/20	06/29/20	0y		428 / 220	6.7	32.7	0.09	0.162	708 / 375	810 / 432	906 / 486	2.79
12/05/19	12/13/19	Оy	PORT	399 / 204	35.7	32.8	0.094	0.052	691 / 366	804 / 429	914 / 490	3.76
05/09/19	05/17/19	2у	PORT	423 / 217	32.4	33.5	0.106	0.026	705 / 374	809 / 432	917 / 491	2.44
10/24/18	11/02/18	0y		412 / 211	24.0	33.3	0.03	0.037	694 / 368	793 / 423	883 / 473	1.32
05/01/18	05/09/18	2у	PORT	412 / 211	7.5	34.2	0.04	0.019	710 / 376	809 / 432	902 / 484	1.67





Historical Comments

12/05/19	Oil is suitable for continued use. Remember to please include the time on oil when submitting oil samples for evaluation. Oil can be sent in for testing in one year.N/A
05/09/19	Oil is suitable for continued use. Please re-submit sample in 1 year. Acid number is normal, but has risen since the last sample, monitor at next test interval. Very light debris is noted by the lab.
10/24/18	Fluid is suitable for continued use. Please re-submit annual sample in October 2019. Please include time on the unit and time on the fluid on next sample entry.
05/01/18	Fluid is suitable for continued use. Please submit sample on May 1, 2019All parameters of the fluid look above satisfactory. There is some light visible debris that may be filtered out safely during any future shutdowns.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.