

TPC800LNE

Customer: PTRHTF40122
 VAN DE RAA MEAT & MORE
 BOLDERWEG 45
 ALMERE, 1332 BA Netherlands
 Attn: Wilbert Snijers
 Tel:
 E-Mail: w.snijers@klt.nl




System Information
 System Volume: 1400 ltr
 Bulk Operating Temp: 527F / 275C
 Heating Source:
 Blanket:
 Fluid: PETRO CANADA PETRO-THERM
 Make: WANSON



Sample Information
 Lab No: 02362791
 Analyst: Matthias Voss
 Sample Date: 06/26/20
 Received Date: 07/03/20
 Completed: 07/07/20
 Matthias Voss
 Matthias.Voss@petrocanadalsp.com

Recommendation:

Comments: Acid Number (AN) is abnormally high, but no indication for corrosion wear.




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
06/26/20	07/03/20	9y		381 / 194	78.9	31.4	0.35	0.162	706 / 374	807 / 431	903 / 484	3.87
01/24/19	02/04/19	7y		417 / 214	40.7	31.9	0.282	0.070	675 / 357	784 / 418	888 / 475	5.05
01/19/17	01/27/17	5y		378 / 192	60.1	32.5	0.07	0.059	715 / 380	809 / 432	909 / 487	1.08
Baseline Data				433 / 223		34.2	0.03		720 / 382	817 / 436	900 / 482	1.00





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
06/26/20	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
01/24/19	2	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
01/19/17	3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Baseline Data			0	0						0			0	0					0				0	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments

01/24/19	Acidity crept upwards, however 2 years since last sample, no abnormal elemental analysis detected as a result. Flash point improved from previous sample, this has been recovered. Suggest monitoring at next sample frequency of 1 year to check on acid number creep if it does and take action then. No other immediate areas for concern Acid Number (AN) is abnormally high.
01/19/17	Oil appears fit for further service. Suggest sample at next scheduled maintenance interval. COC Flash Point is marginally low.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.