




STILLYARD HOT OIL SYSTEM



Customer: PTRHTF10094	System Information	Sample Information
CERTAINEED CORPORATION - OXFORD 200 CERTAINEED RD OXFORD, NC 27565 USA Attn: Seth Newton Tel: (919)693-1141 E-Mail: Seth.newton@saint-gobain.com	System Volume: 0 gal Bulk Operating Temp: 0F / -18C Heating Source: Blanket: Fluid: PETRO CANADA PETRO-THERM Make:	Lab No: 02363011 Analyst: Gaston Arseneault Sample Date: 05/12/20 Received Date: 07/06/20 Completed: 07/07/20 Gaston Arseneault gaston.arseneault@petrocanadalsp.com

Recommendation: Despite the dark appearance, which is normal for hot oils, the sample shows nothing abnormal or marginal to act upon. Re-sample at next scheduled interval.

Comments:




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
05/12/20	07/06/20	5m		457 / 236	22.8	34.9	0.15	0.191	723 / 384	813 / 434	912 / 489	1.08
02/15/19	02/28/19	1m	DRAIN POINT	435 / 224	9.7	34.8	0.158	0.029	698 / 370	788 / 420	892 / 478	1.34
11/25/15	11/27/15	0m				34.2	0.134					
04/15/15	04/21/15	0m				34.26	0.196					
12/03/14	01/05/15	0m				33.57	0.418					
Baseline Data				433 / 223		34.2	0.03		720 / 382	817 / 436	900 / 482	1.00





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
05/12/20	6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
02/15/19	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
11/25/15	2	0	0	0	0	0	0	0	0	0	0	4	0	0	0	0	0		0	0	0	0	0	0
04/15/15	2	0	0	0	0	0	0	0	0	0	0	4	0	0	0	0	0		0	0	0	0	0	0
12/03/14	2	0	0	0	0	0	0	0	0	0	0	4	0	0	0	0	0		0	0	0	0	0	0
Baseline Data			0	0						0		0	0					0				0		

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments

02/15/19	Glad to see this system back on our normal Hot Oil testing program. All parameters are within acceptable limits, contamination by water is barely detectable, oxidation is very mild. Keep monitoring along with the other systems. No action needed at this time.
11/25/15	Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the fluid is suitable for further service.
04/15/15	Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample. All component wear rates are normal. There is no indication of any contamination in the component. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.
12/03/14	No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the fluid. The AN level is acceptable for this fluid. The condition of the fluid is suitable for further service.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.