


Customer: PTRHTF20087	System Information	Sample Information
Celanese Eva Performance Poly	System Volume: 0 ltr	Lab No: 02364782
4405-101 AVE.	Bulk Operating Temp: 212F / 100C	Analyst: Yutong Gao
P.O. 428	Heating Source:	Sample Date: 06/22/20
EDMONTON, AB T5J 2K1 Canada	Blanket:	Received Date: 07/15/20
Attn: Greg Hein	Fluid: PETRO CANADA CALFLO AF	Completed: 07/28/20
Tel:	Make:	Yutong Gao
E-Mail: greg.hein@celanese.com		yutong.gao@petrocanadalsp.com

Recommendation: The current fluid has normail viscosity, flash point and solid content. The Acid Number is low, meaning there is minimum oxidation. the 192 ppm Fe indicates that there is minor contamination, which need to be monitored in the future. Please continue to run the current fluid, pay attention to the system contamination control and take one sample in 12 months to compare the fluid conditions.

Comments:

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
06/22/20	07/15/20	0h		439 / 226	18.4	33.3	0.15	0.069	705 / 374	798 / 426	911 / 488	0.76
08/21/17	08/28/17	0h	REACTOR	406 / 208	13.9	31.1	0.05	0.573	700 / 371	799 / 426	897 / 481	1.09
03/01/16	03/02/16	0h	REACTOR PIPING	432 / 222	7.2	32.6	0.09	0.090	699 / 370	800 / 427	899 / 482	1.26
07/26/13	08/01/13	0h	REACTOR DIPING	415 / 213	137.4	36.3	0.13	1.90	684 / 362	789 / 421	890 / 477	3.38
08/24/12	09/05/12		CALFLO TANK	423 / 217	86	33	0.11	0.463	689 / 365	785 / 419	888 / 475	2.786





Historical Comments

1.5

0.5

Vov29/02 Dec15/04 Jan 13/06 Jan 15/10

Nov30/07

May25/12 Jul26/13 Aug21/17

Apr20/11

08/21/17	Based on the analysis results, it appears the oil is experiencing some contamination. Please note the wear element iron (Fe). Iron typically comes from the system components. The pentane insolubles analysis result is the determination of contaminants in used heat transfer oils, and is used to determine the amount of insoluble materials such as oxidation by products, dirt, carbonaceous material, and system wear components in the fluid. These contaminants are group are called pentane insolubles and the result is supported by the PQ result. It also appears that the sample results are not consistent with previous samples. Improper sampling techniques could result in unreliable test results. Iron ppm levels are severe. Pq levels are severe. Pentane insolubles levels are severely high.
03/01/16	Results are normal. Resample at the next interval and continue to monitor the system.
07/26/13	There is high iron, solids and water in the sample. This is indicative of a poorly flushed sample port. Please flush at least 1 L of oil prior to collecting sample. The other test parameters indicate that the oil is in good condition and is suitable for further use. Please conitnue to sample on an annual basis. Iron ppm levels are severe. PQ levels are severe. Pentane Insolubles levels are severely high.
08/24/12	The oil results are close to previous results. It shows a long history if high solids in the oil and high iron content. If there is a filtration system on the oil we suggest to user finer filters to filter more of the insoluble particles that are visible in this testing. Re-sample at next normal interval

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.

300°0

250°C

200°C

150°C 100°C

> % % 20% 30% 10% 50% Percent Recovered

5,000

4 000 3,000

2,000

1.000

നഗശ