

HEAT TRANSFER

Customer: PTRHTF30101

Roseburg Pembroke MDF Inc. 777 Fibreboard Drive

Pembroke, ON K8A 6W5 Canada

Attn: Dan Havis Tel: (613)732-3939

0.10

0.00

May11/1

E-Mail: danielh@rfpco.com

System Information

System Volume: 100000 ltr

Bulk Operating Temp: 518F / 270C

Heating Source:

Blanket:

Fluid: PETRO CANADA PETRO-THERM

Make:

Sample Information

Lab No: 02368793 Analyst: Pierre Castagne Sample Date: 07/30/20 Received Date: 08/06/20 Completed: 08/18/20 Pierre Castagne

205

200

195

May12/17


Oct30/17

Jul30/20

pierre.castagne@hollyfrontier.com

Recommendation: Potassium & Pentane Insolubles are very high, acid number is high, viscosity is higher then an ISO VG 32 should be. GCD @50% is high. Verify the source of the potassium (could be using same transfer equipment for other oils). Resample at your regular sample schedule

Comments: Potassium ppm levels are severely high. Pentane Insolubles levels are severely high. (GCD) 90% Distillation Point is marginally high.



25

20

1119/20

Jan 31/20

0ct30/17

Mav12/1

Abnorma


May12/17

0ct30/17

Jan 31/20



Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



The Potassium level are severly high, Acid Number (AN) is high, GCD @ 90% is high, GCD % <335C is high, Pentane Insolubles is high. With the high level of Potassium, we suspect product contamination, please verify the possible source of contamination. There is some thermal degradation of the oil. Re-sample the oil at regular sample date. Potassium ppm levels are severely high. Acid Number (AN) is abnormally high. (GCD) 90% Distillation Point is marginally high. Potassium PPM levels are severely high. Pentane Insolubles are severely high. Acid number (AN) is abnormal high. Resample to confirm finding. Potassium ppm levels are severely high. Acid Number (AN) is abnormally high. Apart for high Iron, the sample looks goodPQ levels are abnormal. Iron ppm levels are abnormal. (GCD) 90% Distillation Point is marginally high. GCD @ 90% are very high, this impacts the viscosity and carbone deposit. (GCD) 90% Distillation Point is severely high.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.