


HEATER SYSTEM


Customer: PTRHTF60022	System Information	Sample Information
TECNILUB LTD	System Volume: 20000 ltr	Lab No: 02369118
ALCALDE PEDRO ALARCON 726	Bulk Operating Temp: 90F / 32C	Analyst: Peter Harteveld
SAN MIGUEL	Heating Source:	Sample Date: 07/22/20
SANTIAGO, 8900110 Chile	Blanket:	Received Date: 08/07/20
Attn: Andres Hermosilla	Fluid: N/A	Completed: 08/11/20
Tel: 1(562)273-1300	Make: CHINESE HEATER	Peter Harteveld
E-Mail: andres@TECNILUB.CL		peter.harteveld@petrocanadalsp.com

Recommendation: This is baseline data of a fresh unknown Chinese made AB based heat transfer fluid. Since the product brand name is unknown there is no reference data. The viscosity of the fluid is lower than shown in e-mail information. The Flash Point is higher. This can be related to the test method used (Cleveland Open Cup vs. PM Closed Cup). The measured distillation temperature range of the fluid is close to that of the e-mail info. It is recommended to take another sample 24 hours after system start-up when the fluid has reached its stable operating temperature.

Comments:

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
07/22/20	08/07/20	0h	DRUMS	432 / 222	13.3	22.6	0.01	0.039	716 / 380	768 / 409	800 / 427	0.00





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.