




[06-12-044-13W5] H-1611


Customer: PTRHTF20227	System Information	Sample Information
PEYTO EXPLORATION Box 7198 EDSON, AB T7E 1V4 Canada Attn: Cory Pambrun Tel: (780)712-0217 E-Mail: cpambrun@peyto.com	System Volume: 0 ltr Bulk Operating Temp: 383F / 195C Heating Source: Blanket: Fluid: PETRO CANADA PETRO-THERM Make: HEAT TECH	Lab No: 02374012 Analyst: Terry Veenstra Sample Date: 08/27/20 Received Date: 09/03/20 Completed: 09/08/20 Terry Veenstra terry.veenstra@petrocanadalsp.com

Recommendation: Sample results show that fluid is still good condition. GCD looks good, Pentane Insolubles are low and Flash Point is high. Resample in 6 months.

Comments:




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
08/27/20	09/03/20	6y		453 / 234	1.5	26.9	0.02	0.028	722 / 384	805 / 430	918 / 492	1.46
02/19/20	02/21/20	5y	5 WAY METER	428 / 220	0.00	32.8	0.020	0.079	708 / 376	786 / 419	881 / 472	0.00
08/21/19	08/22/19	4y		457 / 236	0.00	35.2	0.020	0.099	726 / 385	808 / 431	906 / 486	0.00
02/19/19	02/21/19	3y		432 / 222	9.3	31.6	0.052	0.023	719 / 381	807 / 431	911 / 489	0.91
11/26/18	11/29/18	3y		343 / 173	2.6	27.5	0.01	0.039	660 / 349	746 / 396	842 / 450	4.23
Baseline Data				433 / 223		34.2	0.03		720 / 382	817 / 436	900 / 482	1.00





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
08/27/20	0	0	0	0	0	0	0	0	0	0	0	0	2	0	0	0	0	0	0	0	0	0	0	0
02/19/20	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
08/21/19	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	3	0
02/19/19	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
11/26/18	1	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	1	0	0	0
Baseline Data			0	0						0			0	0					0				0	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments	
02/19/20	GCD @ 90% is marginally low. Lighter ends should be vented off the system at regular intervals as good fluid maintenance practice. This should get rid of the low boilers in the system. Resample in 6 months. (GCD) 90% Distillation Point is marginally low.
08/21/19	This sample indicates that the in service oil is good for continued use. Continue to vent periodically as part of a good maintenance program and resample in 6 months.
02/19/19	This fluid has greatly improved since the pressure has been reduced and the system has been vented. Continue to vent periodically as part of a good maintenance program and resample in 6 months.
11/26/18	The condition of the fluid shows signs similar to thermal degradation but as commented previously this is most likely the effect of too high pressure blanket gas. The Flash Point has decreased further and the distillation curve is low as a whole. Percentage low boiler vapors has increased to 4.23%. This will become problematic for the pumps at 7-8%. Since this is probably the result of blanket gas ingress it looks like natural gas is still in use. The use of N2 is recommended. Please re-sample in 6 months. When sending in the sample please list system volume. Fluid is suitable for further use. (GCD) 90% Distillation Point is severely low. COC Flash Point is abnormally low. (GCD) 10% Distillation Point is marginally low. (GCD) 50% Distillation Point is marginally low.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.