


HOT WAX AREA

Customer: PTRHTF10102	System Information	Sample Information
METALSA INCORPORATED	System Volume: 4000 gal	Lab No: 02378293
301 BILL BRYAN BLVD	Bulk Operating Temp: 240F / 116C	Analyst: Joe Goecke
HOPKINSVILLE, KY 42240 USA	Heating Source:	Sample Date: 09/01/20
Attn: CHRIS HIGGINS	Blanket:	Received Date: 09/28/20
Tel: (270)305-1347	Fluid: PETRO CANADA PETRO-THERM	Completed: 10/06/20
E-Mail: chiggins@kimbrooil.com	Make:	Joe Goecke
		Joe.goecke@petrocanadalsp.com


Recommendation: Still seeing higher than desired Acid Number and continuing dirt load that could damage the system over long term. Should consider planning for a fluid change in next 3-6 months or other maintenance procedure.

Comments: Pentane Insolubles levels are severely high. Acid Number (AN) is severely high.

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
09/01/20	09/28/20	Oy		421 / 216	67.3	36.8	3.71	0.577	709 / 376	808 / 431	911 / 488	2.08
11/28/19	11/29/19	0y		421 / 216	42.4	37.9	4.36	1.10	691 / 366	793 / 423	902 / 483	2.71
05/21/19	05/22/19	0y		410 / 210	44.8	38.2	4.30	0.580	698 / 370	798 / 426	910 / 488	1.61
01/03/19	01/10/19	4y		414 / 212	20.6	37.3	3.78	0.205	681 / 360	784 / 418	893 / 479	3.37
07/31/18	08/01/18	Oy		414 / 212	39.8	36.8	2.77	0.236	703 / 373	786 / 419	867 / 464	0.00







Historical Comments

11/28/19	Although acid numbers is very high this system tends to run high. However combining this with the increase in pentane insoluble material could indicate an increase in oil breakdown or contamination. The flash point, viscosity and low boilers are all good which does not indicate breakdown. I suggest resampling in 30 days and look for possible sources of contamination that could contribute to acid number. Pentane Insolubles levels are severely high. Acid Number (AN) is severely high.
05/21/19	Acid number increased again but not as much as last jump. Oil does not show signs of degradation. Flash point, low boilers, and viscosity are all in very good range. Continue to use and resample at next scheduled interval. Pentane Insolubles levels are severely high. Acid Number (AN) is severely high.
01/03/19	Aside from the acid number being extremely high the sample is in excellent condition. The acid number has continued to increase over the past 6 samples. Although this is high wear metals do not show any negative effects from the high acid.Continue to use and look for any possible contaminants that could increase acid number. Acid Number (AN) is severely high.
07/31/18	This sample is very clean and looks to be in very good condition with the only exception being the high acid number which is difficult to explain unless some acidic material was added and is always high. The remaining properties of this look like new oil. Very little water, great flash point and viscosity and no light ends forming. No action needed a time. Acid Number (AN) is severely high. (GCD) 90% Distillation Point is abnormally low.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.